

Package Name Rate Contract for 11 KV V Cross Arm and 33 KV V Cross Arm to TPSODL

Bidder :

Note : The said format to be used only for Technical Pre-Bid Query. Any Commercial Query has to be strictly in Format B2 Format for Commercial Pre-Bid Query and sent separately
Format to be used for query regarding Technical Pre-Qualification Requirement, Safety Pre-Qualification Requirement, Technical Set of Document

Pre-Bid Query has to be sent in editable Excel file format only

Pre-Bid Query has to be sent through e-mail in TPSODL E-Tender System

Sr. No.	Detailed Reference to TPSODL Technical Document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	TPSODL Response
1	2	3	4	5
1	ENG-HV-029, Page No: 3 of 9 & 8 of 9	4.0 GENERAL TECHNICAL REQUIREMENTS & CONSTRUCTIONS	33KV V Crossarm along with Back Clamp / F Bracket or Not. (Approximate weight shall be 22kg will come with Back Clamp only kindly clarify)	Supply of V Crossarm shall be along with Back Clamp & required Nut Bolts. Drawing for Back Clamp & Cross arm will be finalized during detailed engineering.
			11KV V Crossarm along with Back Clamp / F Bracket or Not.	Supply of V Crossarm shall be along with Back Clamp & required Nut Bolts. Drawing for Back Clamp & Cross arm will be finalized during detailed engineering.