

Tender No :-TPSODL/OT/21-22/039				
Package Name:-Rate Contract for supply of LT cables for the period of One year				
Reply to Technical and Commercial Additional Pre-Bid Queries				
Sr. No.	Detailed Reference to TPSODL Technical Document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	TPSODL Response
1	2	3	4	5
1	Technical Specification 1.1 kV LT Power cable of various sizes (page-9 of 19 Clause-5	2C Core compacted Circular/shape	We Will provide you cable for size UP to and including 10 Sqmm compacted Circular.16 Sqmm and above sector shaped (Kindly Confirm)	Accepted
2	Technical Specification 1.1 kV LT Power cable of various sizes (page-10 of 19 Clause-5	Bright Red line shall represent - R ph BrightYellow line shall represent - Y ph Bright Blue line shall represent - B ph For 150 sq. mm. and above, the colored line shall be (3 mm width X 0.5 mm depth from insulation surface)extruded/embedded on the insulation surface.Below 150 sq. mm, the colored line shall be (2 mm width X 0.3 mm depth from insulation surface) extruded/embedded on the insulation surface.For neutral, as core is already black, extruded line is not required.	We Will provide you cable Red, Yellow, Blue & Neutral Black (kindly Confirm)	Accepted
3	Technical Specification 1.1 kV LT Power cable of various sizes (page-12 of 19 Clause-6	Following details shall be printed on both sides of outer sheath at regular interval of every meter and 180°apart:	We will provide you Printing /Embossing on one side of Outer sheath and not provide at 180 degree (Kindly confirm)	Accepted
4	Technical Specification 1.1 kV LT Power cable of various sizes (page-10 of 19 Clause-6	The laid up cores shall be provided with an inner sheath applied by pressurized extrusion process	We will provide you sleeve extrusion process. (Kindly confirm)	Accepted