

Corrigendum No. – 1

Tender Enquiry No- TPSODL/OT/2021-22/005

Work Description - Rate Contract for Grid Audit at TPSODL.

Revised calendar of events will be as follows: -

(a)	Last Date of receipt of Tender Fee	10.06.2021 ; 15:00 Hrs
(b)	Date & Time of Pre-Bid Meeting (If any)	Not Applicable
(c)	Last Date of receipt of pre-bid queries, if any	12.06.2021 up to 15:00 Hours
(d)	Last Date of Posting Consolidated replies to all the pre-bid queries as received	17.06.2021 up to 15:00 Hours
(e)	Last date and time of receipt of Bids	25.06.2021 up to 15:00 Hours
(f)	Date & Time of opening technical bids & EMD	25.06.2021 up to 16:00 Hours
(g)	Date & Time of opening of Price of qualified bids	Will be notified to the successful bidders through our website / e-mail.

In addition to the detailed scope of works mentioned in Annexure-II (Point-5 Detail Scope of Work) of tender document, the following requirement will be considered in bidder's scope.

- 1) Bidder shall provide AC supply to the PSS for carrying out the required testing through a suitable generator set. This is required during outage of 33kV line on which 33kV/440V, 100 kVA Local Transformer is located in PSS.”
- 2) All Rating Transformer Vector Group Test.
- 3) Transformer Neutral Current Transformer (REF & SEF For Protection) Testing if available
- 4) Transformer WTI Current Transformer Testing.
- 5) Numerical Relay Testing Kit should be Capable for Testing of Differential and Directional Over Current Protection.2 Numbers Current Source (At least one Channel Maximum Up to 30A Current Source Required), One Voltage Source channel required.
- 6) Numerical Relay Test Kit shall be Capable for vary the Output Analog Parameter Voltage, Current, Phase Angle, Frequency.
- 7) Station Battery Individual Battery Voltage Measurement.
- 8) All rating of Switchgear Auxiliary Contact NO, NC Changeover Contact Checking.
- 9) Switchgear Anti pumping Circuit Checking.
- 10) All Electromechanically Relay Coil Pickup / Dropout and Relay Auxiliary Contact Checking.
- 11) Earth Pit Resistance, Grid Resistance Measurement Every Equipment.

Warm's Regards,
Shubhranshu Shekhar Sahu | Contracts

Web www.tpsouthernodisha.com

TP SOUTHERN ODISHA DISTRIBUTION LIMITED
(A Tata Power and Odisha Government Joint Venture)

Courtpeta | Berhampur | Ganjam | Odisha - 760 004.

Note-This document does not require signature.