## 1 Format for Technical Pre-Bid Queries- TPSODL/OT/2021-22/058

## Rate Contract for Supply of 33 kV & 11 kV Insulators of various Sizes at TPSODL.

Sr. No.	Detailed Reference to TPSODL Technical Document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	TPSODL Response
1	2	3	4	5
1	11 KV Polymer- Disc insulator 45 KN (T&C)-	No Technical specification provided.	No Technical specification provided.	Attached
2	11 kV 70 kN (B&S) Disc Polymer Insulator with hardware Fitting	No technical specification provided.	Please confirm,We are manufacturer of Polymeric Insulators only, hardware fittings are out of scope of manufacturing and supply. Kindly confirm can we quote only for Insulators. (Please make an differnet tender for Hardware fitting)	Tender T & C Shall be applicable.
3	Pin Insulator Polymer 33KV 24MM FRP DIA with hardware fitting		Minimum failing load 10 kN achieved with 34 mm FRP minimum. Can't be achived with 24 mm FRP. Kindly confirm can we quote with 34 mm FRP.	Tender specification to be complied
4	Disc Insulator 33KV B&S Type 70 kN Polymer with hardware fitting-		Please Note our supply limited up to insulator only, hardware fittings are out of scope of manufacturing and supply. Kindly confirm can we quote	Tender T & C Shall be applicable.
5	Post Polymer Insulator for 33 kV with H/W		Kindly confirm required insulator height. Please Note our supply limited up to insulator only, hardware fittings are out of scope of manufacturing and supply. Kindly confirm can we quote.	Insulator height shall be as per relevant IS/IEC
6	Lot-2		In Lot-2 all insulator are porcelain type. Which are out of our scope of supply (Shall we quote part tender ?)	Tender T & C Shall be applicable.
7			Please make an differnet tender for Hardware fitting as this is a different items and Insulators manufacturer are not make the same.	Tender T & C Shall be applicable.
8				