

Prebid Queries Response- Repair & Reconditioning of Distribution Transformers of various ratings at TPSODL

Sr. No.	Detailed Reference to TPSODL Technical Document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	TPSODL Response
1	2	3	4	5
1	Anexure 2 Clause No. 5.3 page no.32 (General conditions for carrying out repairing job) Limits for MAX " NO LOAD & LOAD LOSSES" in Watts	Mention that 1) Losses of transformers shall be as per rating plate and no tolerance shall be accepted.2) Tolerance on losses to be approved by TPSODL.	We hereby clarify that the following points 1) The losses of Repair Transformers can not be matched as per the original name plate of manufacturers because the transformers used in the fields and repair time to time different repair units as a result NO load & load losses can not be matched in the original specification. So accept the as actual NO LOAD & LOAD LOSSES at the time of repair of transformers at repairers works. 2) The tolerance on losses derived after repair of transformers as actuals . Kindly consider the actual facts .	The distribution transformer shall be tested as per testing code & procedure as per IS 1180 (Part 1): 1989 with all amendment as of date for calculating the losses after repairing. No positive tolerance shall be allowed on the maximum losses displayed on the original name plate of manufacturers for both 50% & 100% loading values.Tolerance will only be accepted near the original manufacturer guaranteed loss.
Sr. No.	Detailed Reference to TPSODL Tender Document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	TPSODL Response
1	2	3	4	5
1	Event of information scope of works clause no 1.7(Qualification criteria)	The bidders should have annual average turnover Rs.4 crores in any of the three financial year from 16-17,17-18,18-19,19-20 and 20-21. Audited balance sheet and PL account required	We are the MSME unit in the state of Odisha. Only we are repairing activities under all DISCOM of odisha.. The repairing allotment both of utilities proportionately distributed among all the repairing units so turnover limit not so high as per the allotment of burnt DTRS quantity. If we consider your qualification criteria of repair quantity 300 numbers within three years so turn over amount should be very less than your declared turnover amount.Though average annual turnover amount should be reduced 40-50 lakhs so that all MSME repair unit can participate the above tender in this Pandemic situation . Kindly consider our appeal .	Tender T & C shall prevail. We have already kept special relaxation for MSME BA.
2	Event of information scope of works clause no 7.1 page no 13(Special condition of contracts,Security Deposit against assets lifted)	Bidders should have furnish additional lifting Guarantee of 10% of (50%of RC value) before lifting & balance 50% at the time of lifting of Burnt DTRS from TPSODL stores valid till return the transformers to TPSODL stores.The repairer is also submit performance guarantee 10%of total repair charges for guarantee period + 1 month & to the sole discretion of TPSODL management with a provision for extension up to another 6 month if required by TPSODL.	We are limited resources of finance with limited BG approval from our Banker.if such type of BG prepared for a single PO we will pay un necessary BG commission & full utilisation of BG limit. As per guide line of MSME act for a SSI unit lum sum BG for one time & required to extension when required . We request you kindly allow to deposit one time Security cum Performance BG for entire RC as per previous practice of OPTCL/TPCODL,TPWODL,TPNODL & TPSODL & other utilities.Kindly allow to deposit one time SPBG.	Tender T & C shall prevail.
3	Event of information scope of works clause no 7.1 page No-14 (Delivery Period)	Transformers shall be lifted from concerned stores & delivery period shall be 60 days from the date of lifting of Transformers from TPSODL stores where as clause No 5.1.1 of annexure 2 page No-30 mentioned that total time frame for delivery of repaired Transformer 115 days from the date of lifting of Transformer from TPSODL stores.	Both the words are confusing & Which one is correct. Please clear our doubt.	SCC of tender shall supersede any other clause mentiend in the tender. Delivery period shall be 60 days from the date of lifting of transformer from TPSODL Stores.
4	Event of information scope of works clause no 7.5 page No-14 (Payment terms)	Payment will be release within 45days from the date of submission of certified bills where as in GCC clause no 6 page no.58 mention that TPSODL will make 100% payment within 30days of submission of invoice complete in all respect.	Both the words are confusing & Which one is correct. Please clear our doubt.	SCC of tender shall supersede any other clause mentiend in the tender. Payment shall be made within 45 days post successful delivery.
5	Clause no 8.0 of GCC page no.59 (Security cum performance deposit)	Associates shall submit SPBG within 15days from the date of issue of RC that 5% of RC till gurantee period +1month.	As per the Finance notification GOVT. of India as well as GOVT. of Odisha declare that SPBG applicable @3% instead of 5& 10% respectively.Kindly allow to deposit 3% SPBG instead of lifting BG,Performance BG . and Security BG.Kindly consider appeal.	We have already kept special provision for MSME BA from Odisha. PBG for MSME BA shall be @25% of total applicable value of SPBG. Lifting and other BG shall be applicable as per tender T & C.
6	Clause no 7.0 of Annexure 2 page no.40 (Gurantee Period)	The repair transformer shall be guaranteed a period of 24months from the date of commissioning or 36months from the date of receipt of transformers at TPSODL store whichever is erlier.	As per present repair work orders norms of all DISCOMS gurantee period of repair Transformers 12months of Comisioning or 18 months from date of suply whichever is earlier in the case of only repair DTR. Kindly amend your gurante clause.	Tender T & C shall prevail.
7	Clause no 14.0 of GCC page no.68 (Liquibated damages)	For delay of each week and part thereof from the deliver schedule specified in the contract . 1% of contract value has to levy LD on the entire contract value subject to a maximum 10%	As per present repair work orders norms of all DISCOMS late deliver penalty imposed from 0. 5% to maximum 5% as per guideline of MSME Act those units are under registration under GOVT. of Odisha . Kindly amend your penalty clause.	Tender T & C shall prevail.

Sr. No.	Detailed Reference to TPSODL Technical Document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	TPSODL Response
1	2	3	4	5

Sr. No.	Detailed Reference to TPSODL Technical Document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	TPSODL Response
1	Qualification Criteria/Clause No 1.7/Page No. 5 of 99	The bidder should have average annual turnover of Rs. 4 Crores in any of the three financial years from (FY 16-17, FY 17-18, FY 18-19, FY 19-20 & FY 20-21). Audited balance sheet, profit and loss account and auditors report from the statutory auditors of the company required). • The bidder should have repaired at least 300 Nos. of distribution transformers (3 Phase /1 phase, 11/230 kVA or 11/ 0.430) of rating, 10 KVA to 500 kVA during the last 3 years. Copy of work order/completion certificate to be submitted in this regard.	Whether The bidder should have average annual turnover of Rs. 4 Crores in any of the three financial years from (FY 16-17, FY 17-18, FY 18-19, FY 19-20 & FY 20-21). or The bidder should have repaired at least 300 Nos. of distribution transformers (3 Phase /1 phase, 11/230 kVA or 11/ 0.430) of rating, 10 KVA to 500 kVA during the last 3 years. OR BOTH CRITERIA ARE REQUIRED.	All criteria mentioend in QR must be fulfilled.

Sr. No.	Detailed Reference to TPSODL Technical Document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	TPSODL Response
1	2	3	4	5
1	Qualification Criteria/Clause No 1.7/Page No. 5 of 99	The bidder should have average annual turnover of Rs. 4 Crores in any of the three financial years from (FY 16-17, FY 17-18, FY 18-19, FY 19-20 & FY 20-21). Audited balance sheet, profit and loss account and auditors report from the statutory auditors of the company required). • The bidder should have repaired at least 300 Nos. of distribution transformers (3 Phase /1 phase, 11/230 kVA or 11/ 0.430) of rating, 10 KVA to 500 kVA during the last 3 years. Copy of work order/completion certificate to be submitted in this regard.	Whether The bidder should have average annual turnover of Rs. 4 Crores in any of the three financial years from (FY 16-17, FY 17-18, FY 18-19, FY 19-20 & FY 20-21). or The bidder should have repaired at least 300 Nos. of distribution transformers (3 Phase /1 phase, 11/230 kVA or 11/ 0.430) of rating, 10 KVA to 500 kVA during the last 3 years. OR BOTH CRITERIA ARE REQUIRED.	All criteria mentioend in QR must be fulfilled.