

Reply to Technical and Commercial Pre-Bid Queries				
Tender No:-TPSODL/OT/2022-23/026				
Package Name:-Rate Contract for Rate Contract for Supply of Different Size of LT AB Cable for PAN TPSODL.				
Sr. No.	Detailed Reference to TPSODL Technical Document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	TPSODL Response
1	2	3	4	5
1	ENG-ELC-046 / 4-General Technical Requirement /Page No-5/11-b ENG-ELC-061 / 4-General Technical Requirement /Page No-4/ 11-b		Size - 3Cx35+25+16 ,Thickness of insulation is 1.2 mm whereas thickness of insulation in size 4Cx35+35+16 is 1.5 mm  Since Conductor size is same i.e. 35 sqmm , then thickness of insulation should remain same and also as per IS -14255 /Table 4, the thickness for 35 sqmm is 1.2 mm	<b>Specification to be complied</b>
2	ENG-ELC-046 / Clause No 1 / Page No 2 of 20	The sizes specified in specifications are are do not match the <b>BOQ</b> Requirements of annexure - I for Specification For LT AB cable- 3 cores / Insulated messenger / Street Light	Please confirm please confirm which should be followed	<b>BA shall quote the tender as per the Revised BoQ Requirement of Annexure-I. &amp; For - 3 core LT AB Cable, Messenger wire shall be Insulated.</b>