

Format for Pre-Bid Queries :	Commercial		
Tender No :	TPSODL/OT/2021-22/087 dtd.:10.01.2022		
Package Name :	Rate Contract for Supply of 33/11 kV, Power Transformers of Various Ratings		
Name of Bidder :	M/s.Shirdi Sai Electricals Limited, Kadapa, Andhra Pradesh - 516002.		

Sr. No.	Detailed Reference to Tata Power Technical Document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	Tata Power Response
1	2	3	4	5
1	Doc. No. ENG-HV-104/ Clause no.12. Guarantee/ page no.73 of 94	The manufacturers of the transformer shall provide a guarantee of 60 months from the date of receipt of transformer at the stores of the Utility. In case the transformer fails within the guarantee period, the supplier will depute his representative within 15 days from date of intimation by the utility for joint inspection. In case, the failure is due to the reasons attributed to supplier, the transformer will be replaced/repared by the supplier within 2 months from the date of joint inspection.	We bring to your kind notice that many of power utilities procuring the Power transformers with Guarantee period of 24 months from the date of supply or 18 months from the date of Commissioning whichever is earlier.  We request you to please review and amend the Guarantee clause as mentioned above.	As per tender Conditions
2	Clause no.8.0 SECURITY CUM PERFORMANCE DEPOSIT of General conditions of Contract for supply orders/ Page no. 9 of 49	Associates shall submit within 15 days from the effective date of issue of PO/RC, Security Performance Bank Guarantee (SPBG) in the format as per Annexure B of this document from banks acceptable to TPSODL for:  (a) 5% of the PO value if purchase order value is more than Rs 5 Crores. (b) 10% of the PO value if purchase order value is less than Rs 5 Crores.	We request you to amend the clause as per the below:  Associates shall submit within 15 days from the effective date of issue of PO/RC, Security cum Performance Bank Guarantee (SPBG) in the format as per Annexure B of this document from banks acceptable to TPSODL for:  (a) 1% of the PO value if purchase order value is more than Rs 5 Crores. (b) 3% of the PO value if purchase order value is less than Rs 5 Crores. This shall remain valid till the end of the Guarantee Period of contract, plus one month	As per tender Conditions
	<b>TOSHIBA</b>			
1	7.1 Special Conditions of contract	Delivery period shall be 120 days from date of receipt of release order / CAT-A issuance whichever is later.	Delivery period shall be 180 days from date of receipt of release order / CAT-A issuance whichever is later for 1st release order. For subsequent orders the delivery period shall be 150 days from date of receipt of release order.	As per tender conditions
2	NITROGEN INJECTION DRAIN AND STIR SYSTEM	Scope of NIDS	We presume NIDS is not in bidders scope of supply	Refer to Technical clarifications
3	Cl. No. 12.5 Dispatch and Delivery Instructions:  Point No.8	In case of manual unloading, supplier / transporter shall deploy sufficient Labour for unloading the material at TPNODL central store. For heavy item(s), crane will be provided by TPNODL (unloading cost will be recovered from the associate).	As the tendered item is heavy item and unloading is in the scope of bidder, we request you to confirm wheather the crane support is provided or not. If providing inform the charges for crance and unloading at site.	As per tender conditions
	<b>VIII POWER TRANSFORMERS PVT LTD.,</b>			
1		Clause no.1.7.bThe bidder should have executed supply orders of Power Transformer of same rating or higher rating for 100% of the tender quantity during last 3 financial year	5MVA 33/11KV Transformer,they dont have a particular 5MVA 33/11KV rating transformer performance/order supply, But we have higher rating and higher voltage class transformers supplied performance certificate/supply. Kindly consider the same for qualification certificate class no 1.7(B) & (D).	Noted
2		Clause no.1.4 of TS:- The scope of supply includes the provision of type test. The equipment offered should have been successfully type tested within five years from date of tender and the designs should have been in satisfactory operation for a period not less than three years as on the date of order. Compliance shall be demonstrated by submitting, (i) authenticated copies of the type test reports and (ii) performance certificates from the users, specifically from Central	We have a Type test report for 5MVA 33/11KV power Transformer, for 3.15MVA and 8MVA Transformer we will give undertaking stating we will conduct a Type test report on our cost against issue of order on us.	If shortlisted with two weeks type test should be provided otherwise EMD may be forefitted
3				
	SVASCA	Solvency certificate	Kindly provide us the amount for which solvency certificate to be taken.	Page no.23, pont no.17:-Amount not mentioend in tender
	Request for extension for submission of bids for 10 days			