

FORMAT B.1**Format for Technical Pre-Bid Queries****Tender No** TPSODL/--/--**Package Name** Rate Contract for -----**Bidder :** M/s -----

Note : The said format to be used only for Technical Pre-Bid Query. Any Commercial Query has to be strictly in Format B2 Format for Commercial Pre-Bid Query and sent separately
 Format to be used for query regarding Technical Pre-Qualification Requirement, Safety Pre-Qualification Requirement, Technical Set of Document

Pre-Bid Query has to be sent in editable Excel file format only**Pre-Bid Query has to be sent through e-mail in TPSODL E-Tender System**

Sr. No.	Detailed Reference to TPSODL Technical Document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	TPSODL Response
1	2	3	4	5
1		3.9 Type Tests (if applicable) The type tests specified in TPSODL specifications should have been carried out within five years prior to the date of opening of technical bids and test reports are to be submitted along with the bids.	This need to be checked whether applicable	All the test/test reports required shall be as per the Technical Specifications and manufacturer's standard practices.
2	BOQ	In the cassette AC Capacity it is written as 3.2 ton, but manufacturer have either larger or smaller capacity IDU.	Pls clarify on the same	Bidder has to recommend as per the heat load calculations and the over all area and to meet the performance requirements mentioned in technical specifications.
3	BOQ	Signal Receiving unit For Four Way Cassette Units	Pls clarify on the same	As per standard practices and systems of VRV units.
4	Annexure I, pg 18, pg 58	Pg 18: 1.0 SUPPLY OF VRF UNITS Supply of following type VRF units with scroll compressor. Pg 58: 4.1 Outdoor Unit Each modular inverter outdoor shall be DC twin rotary/scroll hermetic compressor.	Can we consider Pg 58 DC Twin Rotary/Scroll Compressor in Outdoor specifications?	Manufacturer to recommend based on usage, cost optimisation and high operational efficiency.
5	Annexure I pg 18	3.1 Individual Remote Control	Can we quote Rate as Zero in items which come as part of the machines?	As per standard practices of VRV units
6	Annexure I pg 19	6c. 4 Core x 6 sqmm Armoured power cabling for VRF ODU's	As per the ODU selection power cable size should be higher. Should we quote as per BOQ or as per actual requirement?	As per OEM recommendation.
7		Also specify the location of the panel in the building from where we will fetch the main power cable to the outdoor unit.	Required Clarification	Cable connection for the Outdoor Units will be routed from the Main LT Panel, located at basement of the building.
8		Also clarify that whether you will provide the isolator in the panel or we have to supply and fix the ODU isolator near the ODU.	Required Clarification	The same shall be in the scope of the bidder.
9		Please confirm that we have to consider the cable tray or not in the price bid.	Required Clarification	Yes, cable tray is to be supplied by the bidder. Cable tray shall be galvanised with 80micron galvanisation.