

Pre Bid Query Tender Enquiry No : TPSODL/OT/2022-23/089 SITC of Transformer Monitoring Unit				
S. No.	Clause No.	Tender Clause Details	Bidder Query	TPSODL Responses
1		Scope of Work of ITC	From various discussion we understood this tender is only for Supply and testing/commissioning. Erection/retrofitting/Installation of TMU in existing panel, Wiring of TMU to TB and Cable termination on TMU Terminal block in existing panel will be done by TPCODL as we don't have information of existing site/panel type/Space availability inside panel/color of panel etc.	Scope of Work is attached separately
2		Delivery Period	Delivery period is mentioned as 60 Days and with present global crisis it will be impossible for us to supply TMU in 60days and request you to change supply period to 20 weeks.	Delivery Period shall be 60 days from the issue of RO or GTP approval whichever is later. ITC will be done within 4 weeks from the date of receipt of site
3			Our TMU will have two no FO port as FO port are used as global standard for RPP/RSTP application to avoid any kind of data propagation delay. We request you to accept both FO and RJ45 Port.	RJ45 Two Port Required PRP / RSTP application Required in TMU