



Corrigendum No. – 3

Date: 03-12-2022

Tender Enquiry No- TPSODL/OT/2022-23/89

Work Description - SITC of Transformer Monitoring Unit

Clause 1.3: Dates in Calendar of events revised as below

		Existing Calendar	Revised Calendar
(a)	Last Date of receipt of Tender Fee	03.11.2022 17:00 Hrs.	06.12.2022 17:00 Hrs.
(b)	Last Date of receipt of pre-bid queries, if any	No Change	No Change
(c)	Date and Time of Pre-Bid Meeting	NA	NA
(d)	Last Date of Posting Consolidated replies to all the pre-bid queries as received	24.11.2022, 17:00 Hrs	No Change
(e)	Last date and time of receipt of Bids	28.11.2022, 17:00 Hrs	08.12.2022, 17:00 Hrs
(f)	Date & Time of opening technical bids & EMD	28.11.2022, 18:00 Hrs onwards	08.12.2022, 18:00 Hrs onwards

Scope of Work of ITC: Attached as Annexure

Rest of the tender document remains unchanged.

Regards,

Chandra Sekhar Sahoo | Procurement

Mob +91 7894441407 | Web www.tpsouththernodisha.com

TP SOUTHERN ODISHA DISTRIBUTION LIMITED
(A Tata Power and Odisha Government Joint Venture)

Courtpeta | Berhampur | Ganjam | Odisha - 760004

Note-This document does not require signature

Installation Testing & commissioning work For TMU

Scope: Bidder should ensure to installation with testing & commissioning of their desire TMU model in requisite panel.

IP level: As the panel of indoor type bidder should supply suitable enclosure to ensure IP level 51 (min).

Installation: Mounting of TMU on the PTR CRP panel with required accessories (CT PT R,Y,B ,N Color coding wire(2.5sq mm), Control wire(1.5 sqmm), disconnecting type TB, lugs, gland & ferrules of suitable size) should be under bidder's scope. Binary input (Buchholz Alarm, Trip / OTI Alarm , Trip /WTI Alarm ,Trip/ PRV Trip/ OSR Trip / MOG Alarm & 4-20mA OTI/ WTI Temperature indicator points(only TB point) shall be provided by TPSODL Team. PSS location and feeder will provided during the course of PO (No extra Freight charges will) . Bidder should arrange proper equipment for mounting of TMU (i.e. Gas cutter/drill machine, etc. shall be arranged by bidder for during installation and testing commissioning).

CT / PT / Control Wiring from CRP panel up to TMU and Commissioning B.A scope.

Power Supply:

- 1) Bidder should supply separate suitable rating MCB with control cable for supply for TMU.
- 2) Control Voltage 24V DC Supply for TMU.

Picture is attached for reference purpose only.

