FORMAT B.1

Format for Technical Pre-Bid Queries
Tender No TPSODL/OT/2022-23/101

Package Name Rate Contract for Supply of V-Cross Arm (11kV) for 9M PSC Poles

Bidder:

Note: The said format to be used only for Technical Pre-Bid Query. Any Commercial Query has to be strictly in Format B2 Format for Commercial Pre-Bid Query and sent seperately

Format to be used for query regarding Technical Pre-Qualification Requirement, Safety Pre-Qualification Requirement, Technical Set of Documnt

Pre-Bid Query has to be sent in editable Excel file fomat only

Pre-Bid Query has to be sent through e-mail in TPSODL E-Tender System

Sr. No.	Detailed Reference to TPSODL Technical Document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	TPSODL Response
1	2	3	4	5
1	Technical Specification / General Technical Requirements / 4.1 / Pg No- 29 of 160	In the general technical requirements point no- 1. Materials - 75x40x4.8mm Channel and in drawing of pg - 34 of 160 the channel dimension is 100mm.	Mismatch found in the general technical requirement and drawing. In the general technical requirements channel size mentioned is 75x40x4.8mm but in the drawing channel size showing as 100mm. Kindly confirm the channel size.	Please consider Channel size 75x40x4.8 mm
2	Technical Specification / General Technical Requirements / 4.1 / Pg No- 29 of 160	In the general technical requirements point no- 1. Materials - 50x50x6mm angle and in drawing of pg - 34 of 160 the 50x50x6mm Plate.	Mismatch found in the technical general technical requirement and drawing. In the general technical requirements angle 50x50x6mm mentioned but in the drawing 50x50x6mm Plate given. Kindly confirm the exact requirement	Please consider 50x50x6 mm plate
3				
4				
5	1			
6				
7				
8				
9				
10				
	+			
	+			