

Sr. No.	Detailed Reference to TPSODL Technical Document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	TPSODL Response
1	2	3	4	5
1	LT Stay clamp requirement is 1000 Pair	There are 4 types of LT clamp details :- 1) LT STAY CLAMP FOR 9 MTR 300KG PSC POLE AT A HEIGHT OF 100MM FROM TOP 1) LT STAY CLAMP (TYPE A) 2) LT STAY CLAMP (TYPE B) 2) LT STAY CLAMP FOR 9 MTR 300KG PSC POLE AT A HEIGHT OF 1000MM FROM TOP 1) LT STAY CLAMP (TYPE A) 2) LT STAY CLAMP (TYPE B)	which one to be consider? kindly send us bifurcated quantity.	Kindly consider Type A.This is the indicative drawing & it will be finalised during detailed engineering at the time of CAT-A approval.
2	HT Stay clamp requirement is 8600 Pair	There are 3 types of HT clamp details given :- 1) HT STAY CLAMP FOR WPB 160X152 GI JOIST 1) HT STAY CLAMP (TYPE A) 2) HT STAY CLAMP (TYPE B) 2) HT STAY CLAMP FOR 150X150 RS JOIST	which one to be consider? kindly send us bifurcated quantity.	Kindly consider Type A.This is the indicative drawing & it will be finalised during detailed engineering at the time of CAT-A approval.