| Sr. No. | Detailed Reference to TPSODL Technical Document. Please specify Document No / Clause No / Page No | Description as per Bid Document | Remarks - Query / Clarification | TPSODL Response |
|---------|---|--|--|--|
| 1 | 2 | 3 | 4 | |
| 1 | Annexure I, Schedule for Items, SI no. 1 | Back Clamp for anticlimbing, device 25X3 mm. flat, 0.59Kg/Mtr. Flat of 0.510mtr length 8 no's = (8x0.59x0.510) | GTP & Drawing not mentioned in Tender Document. Therefore we request you to provide the same. We also request you to confirm the unit of Quantity of this Item. | Please refer 4.0 General Technical Requirement of attached Specification for GTP & Drawing will be finalised during detailed Engineering |
| 2 | Annexure I, Schedule for Items, SI no. 2 | Back Clamp for danger Plate 25X3mm. flat, 0.59Kg/Mtr Flat of 0.510mtr length 1 no's = (1x0.59x0.510) | GTP & Drawing not mentioned in Tender Document. Therefore we request you to provide the same. We also request you to confirm the unit of Quantity of this Item. | Please refer 4.0 General Technical Requirement of attached Specification for GTP & Drawing will be finalised during detailed Engineering |
| 3 | Annexure I, Schedule for Items, SI no. 3 | FLAT GI SIZE 90X6 MM | No such specification mentioned in IS. Kindly give clarity on this material. | FLAT GI SIZE 90X6 MM is required |
| 4 | Annexure I, Schedule for Items, SI no. 6 | FLAT GI SIZE 25X4 MM | No such specification mentioned in IS. Kindly give clarity on this material. | FLAT GI SIZE 90X6 MM is required |
| 5 | Annexure I, Schedule for Items, SI no. 7 | Earthing Conductor For Burial : 75X10 mm (5.89Kg/Mtr.) GI Flat for laying (spacing maximum 2m both ways) | GTP & Drawing not mentioned in Tender Document. Therefore we request you to provide the same. Earthing Conductor & GI Flat both are different items. Hence we require your clarification regarding your requirement of Material. | Please refer Revised Schedule of Items |
| 6 | Annexure I, Schedule for Items, SI no. 8 | Earthing Conductor: 50X6mm (2.4Kg./Mtr.) GI Flat for Raiser from the burial earth mat to equipment, structure etc) | GTP & Drawing not mentioned in Tender Document. Therefore we request you to provide the same. Earthing Conductor & GI Flat both are different items. Hence we require your clarification regarding your requirement of Material. | Please refer Revised Schedule of Items |
| 7 | | Annexure-I - Schedule for Items | Please provide us the drawing of Back Clamp for anticlimbing device (Item SI.No.1) if it is required to be submitted with the BID. | Drawing will be finalised during detailed Engineering |
| 8 | | | Please provide us the drawing of Back Clamp for danger plate (Item SI.No.2) if it is required to be submitted with the BID. | Drawing will be finalised during detailed Engineering |
| 9 | | | 3. Please provide us the drawing of Earthing Conductor (Item SI.No.7 $\&8)$ if it is required to be submitted with the BID. | Please refer Revised Schedule of Items |
| 10 | | | 4. Please clarify whether these GI Flats of various sizes will be fabricated? Then, provide us the drawings. If non-fabricated then specify us the lengths of the GI flats to be supplied. | Fabrication is not required |
| 11 | | | 5. Please confirm the HSN Code of GI Flat - 72123090 ? | HSN Code - 7212 |
| 12 | | | 6. In Annexure-I Item No.3 Flat size mentioned as 90X6 mm whereas in the Technical Specification part of tender it is mentioned as GI Flat 96X6 mm? Please clarify ???? | Flat Size 90X6 mm is required |
| 13 | | Annexure-I - Schedule for Items | Please provide us the drawing of Back Clamp for anticlimbing device (Item SI.No.1) if it is required to be submitted with the BID. | Drawing will be finalised during detailed Engineering |
| 14 | | | Please provide us the drawing of Back Clamp for danger plate (Item SI.No.2) if it is required to be submitted with the BID. | Drawing will be finalised during detailed Engineering |
| 15 | | | 3. Please provide us the drawing of Earthing Conductor (Item SI.No.7 & 8) if it is required to be submitted with the BID. | Please refer Revised Schedule of Items |
| 16 | | | 4. Please clarify whether these GI Flats of various sizes will be fabricated ? Then, provide us the drawings. If non-fabricated then specify us the lengths of the GI flats to be supplied. | Fabrication is not required |