

FORMAT B.1**Format for Technical Pre-Bid Queries****Tender No** TPSODL/OT/2022-23/134**Package Name** Rate Contract for Supply of H.G. Fuse**Bidder :****Note :** The said format to be used only for Technical Pre-Bid Query. Any Commercial Query has to be strictly in Format B2 Format for Commercial Pre-Bid Query and sent separately

Format to be used for query regarding Technical Pre-Qualification Requirement, Safety Pre-Qualification Requirement, Technical Set of Document

Pre-Bid Query has to be sent in editable Excel file format only**Pre-Bid Query has to be sent through e-mail in TPSODL E-Tender System**

Sr. No.	Detailed Reference to TPSODL Technical Document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	TPSODL Response
1	2	3	4	5
1	Specification of 33KV H.G. Fuse 200Amp.	Clause No. 4 i.e. General Technical Requirements.	As per GTR requirement of connector made of Copper Flat vide Sub-Clause No. 14 But As per your drawing it shows that connector to be made of Copper Casting as per Clause No. 19 of GTR	Drawing is for reference purpose only.(Dimensions are for reference purpose only and may change as per Manufacturers Type Tested Design. Design Subject to change during detailed engineering) Specification need to be complied
2	Specification of 11KV H.G. Fuse 200Amp.	Clause No. 4 i.e. General Technical Requirements.	As per GTR requirement of connector made of Copper Flat vide Sub-Clause No. 22 But As per your drawing it shows that connector to be made of Copper Casting as per Clause No. 19 of GTR	Drawing is for reference purpose only.(Dimensions are for reference purpose only and may change as per Manufacturers Type Tested Design. Design Subject to change during detailed engineering) Specification need to be complied
3	Specification of 11KV H.G. Fuse 400Amp.	Clause No. 4 i.e. General Technical Requirements.	As per GTR requirement of connector made of Copper Flat vide Sub-Clause No. 22 But No drawing provided with the tender. So, please clarify whether this is made of Copper Casting or Copper Flat.	GTP to be followed .Drawing is only for tender reference purpose only. Drawing as per TPSODL GTP to be provided by the OEM.