

FORMAT B.1

Format for Technical Pre-Bid Queries

Tender No **TPSODL/OT/2023-24/58****Rate Contract for Supply of 11kV**Package Name **Cross****Arm HT V Shape at TPSODL**

Note : The said format to be used only for Technical Pre-Bid Query. Any Commercial Query has to be strictly in Format B2 Format for Commercial Pre-Bid Query and sent seperately
 Format to be used for query regarding Technical Pre-Qualification Requirement, Safety Pre-Qualification Requirement, Technical Set of Documnt
Pre-Bid Query has to be sent in editable Excel file fomart only
Pre-Bid Query has to be sent through e-mail in TPSODL E-Tender System

Sr. No.	Detailed Reference to TPSODL Technical Document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	TPSODL Response
1	2	3	4	5
1	ENG-HV-2026 / Clause No 18/ Page Number 32 of 158 / OPTION	Rate Contract for Supply of 11kV Cross Arm HT V Shape at TPSODL	<p>In the Work Description the Item mentions as "Supply of 11kV Cross arm HT V Shape" In the Specification number ENG-HV-2026, there are three options of the item :- Option 1 : Arrangement in WPB Pole without Clamp Option 2: Arrangement in WPB and RSJ Pole with Back Clamp 160x160 Option 3: Arrangement in 9m PSC Pole with Back Clamp</p> <p>Please refer Page 27 of 158 Tendere document - General Technical Requirement Table 4 SI No. 5 Weight of the V Cross arm mentioned 10.5kg desired value</p> <p>Our query : the weight of the cross can not be same for all the three above mentioned option 1,2,3.</p> <p>Please specify the exact type required for the Bid submission</p>	<p>CROSS ARM HT V SHAPE FOR 11KV (9 Mtr PSC Pole) without Back Clamp</p> <p>weight 10.5kg (Approx)</p> <p>CROSS ARM HT V SHAPE FOR 11KV (9 Mtr PSC Pole) without Back Clamp</p>