

Consolidated Response to Technical Pre-bid Queries				
Tender No. TPSODL/OT/2023-24/002				
Engineering, Supply, Erection & Commissioning of River Crossing Infrastructure under SDMF-1 on "Turnkey Contract Basis"				
Sr. No.	Detailed Reference to TPSODL Technical Document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	TPSODL Response
1	2	3	4	5
1	NA	NA	No line item for Soil test is included in the BOQ. In generally in river crossing sites piling structure is advised for PC type of tower.	Soil testing is added in revised BOQ /Revised Annexure-I (Schedule of Items) and same is attached
2	TS- ENG-GEN-4027_Technical Specification For GI Channel & Angle, GI Top Bracket	SAIL, JINDAL, RINL & TATA (Billet with re rolling not allowed)	OEM are not agreed to accept the order for small qty below 100 MT with SAIL/ TATA make steel. In river crossing we only have a structure qty 15 TON (PC Type Tower). Hence requested to kindly consider the point only for Tower Structures.	Specification to be complied
3	NA	NA	No piling per Mtr rates are mentioned in the BOQ	Piling cost is added in revised BOQ /Revised Annexure-I (Schedule of Items). Please note that Piling to be taken up if required based on soil test report
4	Boq No - 97	Preliminary survey, Detail survey including but not limited to taking of levels, profile plotting, tower spotting ,marking of towers locations at site UOM- KM	As mentioned in BOQ, UOM is considered as KM, where as we request to change it as per Nos. During actual execution river crossing length is limited to 500 Mtr-600 Mtrs. In this scenario per Km rate quoting is not getting viable.	Please Refer Revised BOQ/Revised Annexure-I (Schedule of Items)
5	NA	NA	Scope of Pile foundation drawing and design ; TPSODL or EPC??	It is in the scope of EPC as per soil test report
6	Tender Pg. No -31	PC + 6 Tower	Please clarify the Height	Kindly refer attached Technical specifications
7	Price Bid	WPB 160x152 (30.44KG/Mtr.),13 mtr- with base plate 300x300x12	This material is GI or MS	GI
8	Price Bid	All Channel , Angle & Clamps	GI or MS	GI