

Format for Technical Pre-Bid Queries

Tender No **TPSODL/OT/2023-24/053**

Package Name **Supply of Insulation Tester and HTCTPTTester at TPSODL**

Sr. No.	Detailed Reference to TPSODL Technical Document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	TPSODL Response
1	2	3	4	5
1	STP FOR INSULATION TESTER MEGGER DIGITAL. Clause: 2.0	IEC 61557-5 : Specification for electrical safety of Low voltage measurement – equipment for testing, measuring or monitoring of protective measures.	Relaxation required for this particular standard	Noted
2	STP FOR INSULATION TESTER MEGGER DIGITAL. Clause: 4.6	Crank Generator: 2-3 r.ps. With moderate strength.	Digitally Operated	Noted
3	STP FOR INSULATION TESTER MEGGER DIGITAL. Clause: 4.11	Required after 5 mins of last operation.	After LastTest completion, the display screen remains ON, but remains in "Power Saving" Kit operates in both Mode, it consumes very very minimum power.The kit is Operational in Mains supply, in case of battery dischrge.	Noted