

Tender No:-TPSODL/OT/2023-24/010				
Package Name:-Rate Contract for Supply of Control Cable for the period of One Year				
Reply to Techno Commercial Pre Bid Querie				
Sr. No.	Detailed Reference to TPSODL Technical Document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	TPSODL Response
1	2	3	4	5
1	ENG-LV-LT Control Cables & Lower Sizes PVC Cu Cables / SI No: 3 / Page No. 9 of 21	2CX16- Inner Sheath- N/A	As per IS-1554-1 inner sheath will be applicable for multicore armored cables, hence the same will be applicable for 2CX16.	Noted
2	ENG-LV-LT Control Cables & Lower Sizes PVC Cu Cables / SI No: 5-5.3 / Page No. 9 of 21	2CX16- Outer Sheath- Nominal thickness- 1.8 mm	Nominal thickness of outer sheath will not be applicable for the armored cables. The thickness will be minimum as per table no. 7 of IS-1554-1	Noted
3	ENG-LV-LT Control Cables & Lower Sizes PVC Cu Cables / SI No: 1-d / Page No. 7 of 21	4CX16- Shape of conductor- Stranded circular	The shape of the conductor will be stranded circular compacted.	Noted