

## Consolidated Response to Technical Pre-Bid Queries

Tender No. TPSODL/OT/2023-24/043

Package Name: Rate Contract for Engineering,Supply, Erection &amp;Commissioning of Multiple Projects under SETU FY 2023-24 on “Turnkey Contract Basis”

Sr. No.	Detailed Reference to TPSODL Technical Document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	TPSODL Response
1	2	3	4	5
1	Annexure - I, Package-B of NIT TPSODL/OT/2023-24/043 for PSS & Associated Lines. <b>Part-B (2X5 MVA PSS), SI No 11</b>	Supply , Installation, Testing and Commissioning OF Transformer Monitoring Unit	Request to provide approved vendors of Transformer Monitoring Unit	<b>1. M/s A Eberle System Pvt. Ltd.</b> <b>2. M/s Schweitzer Engineering Laboratories Pvt. Ltd</b> <b>3. ABB/Hitachi</b>
2	Technical specificationn ENG-EHV-1001 5 MVA & 8 MVA PTR for	Page No-36. <b>XXX.</b> NIDS is to be supplied with transformer unless specified elsewhere in the Bidding document.	Is NIDS to be supplied with Transformer or only provision to be given for future implementation of NIDS. Kindly confirm in this regard.	<b>NOT APPLICABLE for this tender</b>
3		Page No-37. <b>XXXIII.</b> In all conditions transformer shall have provision for future implementations of NIDS.	Also request you kindly provide approved vendors of NIDS system.	<b>NOT APPLICABLE for this tender</b>
4		Page No- 9. <b>VII.</b> Transformer shall be compatible for Operation along with Tap Changer Control panel or Transformer Monitoring Unit (TMU). <b>Supply of TMU is not in scope of Bidder.</b>	Under the Clause (VII) it is mentioned that Supply of TMU is not in scope of Bidder.With reference to above our query is, Is Rate to be quoted for transformer i.e including TMU or excluding TMU because separate TMU item is available at SI.No- 11 of BOQ.	<b>PTR &amp; TMU are separate line items in BoQ.</b> <b>(PTR must be compitable for commissioning of TMU)</b>