

Tender No TPSODL/OT/2022-23/123

Package Name Rate Contract for r Supply of Earth enhancement Material

Note : The said format to be used only for Technical Pre-Bid Query. Any Commercial Query has to be strictly in Format B2 Format for Commercial Pre-Bid Query and sent seperately
 Format to be used for query regarding Technical Pre-Qualification Requirement, Safety Pre-Qualification Requirement, Technical Set of Documnt
Pre-Bid Query has to be sent in editable Excel file fomart only
Pre-Bid Query has to be sent through e-mail in TPSODL E-Tender System

Sr. No.	Detailed Reference to TPSODL Technical Document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	TPSODL Response
1	2	3	4	5
1	4. GENERAL TECHNCIAL REQUIREMENTS, Page No-3/7, SI.No-2	Resistivity of the earth enhancement material- Required is - Less than 0.12 Ohm-m,	Please consider as 0.15 Ohm-m	Tender Specifications to be complied
2	4. GENERAL TECHNCIAL REQUIREMENTS, Page No-3/7, SI.No-8	Weight of material per bag - 20 Kg	Please consider weight of material per bag - 20 Kg or 25 Kg.	Ok Noted
3	We have to quote for Bentonite type or Marconite type			Only bentonite-based EARTH ENHANCEMENT MATERIAL