







Nothern Odisha Distribution Limited TP Southern Odisha Distribution Limited

## **CENTRALIZED CONTRACTS GROUP**

Response to Pre-Bid Queries
NIT No.: TPCODL / CCG / 23-24 / 019

**Tender Description:** 

Rate Contract for Supply of AB Switches of various ratings, At TPNODL, TPCODL, TPSODL & TPWODL.

The pre-bid queries as received against the referred tender enquiry and CCG/CEQG (TP-Odisha) responses on the same are placed below:

S. No.	Tender Reference	Pre-Bid Query raised by Bidder	CCG/CEQG (TP-Odisha) response
1	Tender Clause 1.7 Qualification Requirement	Request to fully exempt the turnover criteria as our firm has not even completed operation for full two years. Firm is MSME registered.	Tender terms shall prevail. Preferential norms for procurement from MSMEs registered in the State of Odisha, shall be applicable as per Annexure – A (page no. 5) of tender document.
2	Technical	Regarding specification of 33 KV AB Switch Clause 4 SI No 43 Connectors/Sockets and in clause 5 SI no 6 the material of the connector are same i.e HD electrolytic copper / Brass.  However regarding specification of 11 KV AB Switch in Clause 4 SI No 44 Connectors and in clause 5, SI no 6 the material of the connector mentioned as below  I) Clause 4 SI No 44 Connectors HD electrolytic copper / Brass is mentioned for connector.	Connectors shall be of HD electrolytic copper or brass as per Technical Specification.
	Specifications	II) But clause 5 SI no 6 it has mentioned HD electrolytic copper Our query is if we can use copper as well as Brass as per our convenience if required kindly clarify. And also clarify if any one of clause 4 General technical requirement and Clause 5 general construction /requirements could be adopted by us as per our convenience if required if any one point regarding particular specification differ from each other.	General Technical requirements and General construction/requirement both should be adopted as per Technical specifications.
3	Technical Specifications	As per TS of both 33KV & 11KV AB Switch, type test from CPRI / ERDA shall only be acceptable. However, it is requested to accept the reports of other Govt. Approved Lab. (like NSIC) also. Kindly review and confirm.	Type test certificate from CPRI/ERDA/NSIC shall only be acceptable.

## Note:

This document shall be an integral part of the tender and bidder shall submit signed/stamped copy of this document along with technical bid, as a token of acceptance. The tender document stands modified to the extent stipulated herein above in this document. All other terms & conditions shall be strictly followed as per Bid documents.

All other terms of Original Tender, remains unaltered.

11.07.2023