

Tender No TPSODL/OT/2023-24/98

Package Name Rate Contract for New Service Connection, LT/HT Line, HT Metering, Go-Swift Works, Small Deposit Works.

Note : The said format to be used only for Technical Pre-Bid Query. Any Commercial Query has to be strictly in Format B2 Format for Commercial Pre-Bid Query and sent separately
 Format to be used for query regarding Technical Pre-Qualification Requirement, Safety Pre-Qualification Requirement, Technical Set of Document
Pre-Bid Query has to be sent in editable Excel file format only

Pre-Bid Query has to be sent through e-mail in TPSODL E-Tender System				
Sr. No.	Detailed Reference to TPSODL Technical Document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	TPSODL Response
1	2	3	4	5
1		Work Description: Rate Contract for New Service Connection, LT/HT Line, HT Metering, Go-Swift Works, Small Deposit Works.	Request provide location details where the works to be carried out.	Location will be across PAN TPSODL, however specific work location will be mentioned during placement of respective RO.
2		Technical specification for the materials not available for the Items listed below. PSC Poles-8M,9M, 10M & 11M RS Joist Poles 9 mtr,10M,11M ,13M Long 150X 150mm (MS/GI) (34.6 Kg Per Mtr.) RS Joist Poles 9 mtr,10M,11M ,13M Long 160X 160mm (MS/GI) (30.44 Kg Per Mtr.) 9 mtr. Long 116x100mm RS joist (MS/GI) (23 Kg Per Mtr.) 11 KV Guy insulator LT Guy insulator 11 KV HW FITTING(B&S) 70KN 3 BOLT 11 KV HW FITTING(B&S) 90KN 4 BOLT 11 KV HW FITTING(T&C) 45KN 11 KV HW FITTING(T&C) 70KN 11 KV HT Stay Set LT Stay Set 160 mm dia HDPE pipe PN 6 PE 80 160 mm dia HDPE pipe PN 4 PE 80 160 mm dia HDPE pipe PN 4 PE 63 160 mm dia HDPE pipe PN 6 PE 63 200 mm dia HDPE pipe PN6 Class PE63 100 mm dia GI Pipe (Heavy Duty) 150 mm dia GI Pipe (Heavy Duty) HUME 200mmdia Heat sriankable Indoor end termination Kit for 11KV Al. XLPE Power Cable (1 Core 3 Core) Heat sriankable Outdoor end termination Kit of 11KV Al. XLPE Power Cable (1 Core 3 Core) LT AB Cable Accessories 11 KV V cross Arm (GI) (10.2 K.g. each) 11 KV Top bracket, Back Clamp, Stay clamp All Aluminium Conductor (AAAC) 232 sqmm , 200 Sqmm. 148 sqmm,100 sqmm,80sqmm,55sqmm Conductor Accessories 40mm, class-B, 3 mtr. long hot dip GI pipe 50mm, class-B, 3 mtr. long hot dip GI pipe. 6 SWG, 8 SWG GI wire GI flat Single pole transformer mounting bracket	Request to provide Technical specification for the materials and approved Vendors	Technical Specification shared
3	BOQ SI.No-293	Providing and fixing including loading , unloading & transportation of FRP Fencing including Flurocent Sticker(two Mtr. in each post),Supply of Latch Lock, Supply of Hings,Supply of SS Lock with Key excluding civil works as per TPSODL specification.	We are unable to understand whether the item included supply & Installation or only installation. Request to clarify.	Supply and installation will be in Bidder scope
4	BOQ (Additional Items beyond Tender BoQ)	Barbed Fencing (size 15'x10')with constn. of retaining wall ,erection of RCC fencing post, Sand filling and metal spreading, Fixing of Iron grill gate etc	Please clarify whether the item includes (Supply + Service) or only service / Installation.	Supply and installation will be in Bidder scope

Sr. No.	Detailed Reference to TPSODL Technical Document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	TPSODL Response
	1.7 Qualification Criteria: Technical Qualification requirements of Sl. No-6 of Page no- 6.	The bidder should have experience in field of similar work (Construction on new / augmentation of LT / HT line) in Project Work, MMG, AMC of 11kV and AMC of 33kV of any distribution utilities during last five years	We have experience in field of similar work (Construction on new / augmentation of LT / HT line) project Work, MMG, AMC of 11kV and AMC of 33kV. But we have successfully completed AMC of 11kv & 33kv under TPCODL and Construction on new / augmentation of LT / HT line work is going on. Based on this work order can we qualify for bidding this tender.	Tender T&C shall prevail. Evaluation will be done accordingly on receipt of your bid document.
			ROW details not mention in the Tender Documents. Kinndly provide the ROW details.	ROW will be taken care by TPSODL and Bidder will actively involve till achieving of complete clearance .
	7.4 Payment Terms:	Payment shall be made within 30 days on submission of error free Invoice by the Business Associate(s) subject to statutory compliance's / Invoice is complete in all respect for each completed item of work location-wise as certified by EIC.	Request to clarify the payment term in detail.	Tender T&C shall prevail