

FORMAT B.1

Format for Technical Pre-Bid Queries

Tender No **TPSODL/OT/2023-24/086**Package Name **Rate Contract for Engineering, Supply, Erection & Commissioning of System strengthening project under SETU FY 2023-24 on "Turnkey Contract Basis.**

Sr. No.	Detailed Reference to TPSODL Technical Document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	TPSODL Response
1	2	3	4	5
1	General	Approved Vendor List of TPSODL	The approved vendor list of following equipments are not available in your Tender documents. 1. CRP 2. Data control Unit 3. Communicabl FPI 4. Sectionalizer 11KV 3PH Pole Mounted	1. CRP - Refer provisional OEM 2 & 3. M/s Sugs Lloyd Private Limited & M/s Siemens 4. Sectionalizer 11KV 3PH Pole Mounted •ABB INDIA •SCHNEIDER ELECTRIC •M/s. Elektrolites (Power) Pvt. Ltd. (MAKE- NOJA POWER) •SHREEHARI ENTERPRISES (Make-Sriwin) •Vishal Transformers & Switchgears Pvt. Ltd (Make-ENTEC)
2	Tender document/ Annexure II	Scope of Work	Please provide the Details of Site locations/Village name/Block/Subdivision for the entire scope of work. Please provide the breakup for scope of work site wise/village wise.	Attached separately
3	General	Approved Vendor List of TPSODL	Most of the vendors listed in the approved vendor list are presently not supplying materials in Odisha Discoms. Please revise the approved vendor list by including the name of present suppliers/ vendors.	The Manufacturer having direct orders from TATA Power Discoms are allowed along with valid type test reports only.
4	2. ANNEXURE I _ BoQ_ Package-A	SI.No- 26 Lightning Arrester (9kV,10kA) DH Class	Against the item under UNIT it is mentioned as 'KG'. Request for clarification.	Revised BOQ is attached
5	2. ANNEXURE I _ BoQ_ Package-A	SI. NO- 95 Lightning Arrester (9kV,10kA) DH Class	Against the item under UNIT it is mentioned as 'EA'. Request for clarification.	Revised BOQ is attached
6	2. ANNEXURE I _ BoQ_ Package-A		For the item in SI. No- 26 and 95 there is contradiction in the Unit, and both the items are same and quantity mentioned are same. Request to clarify in this regard.	Revised BOQ is attached