

CENTRALIZED CONTRACTS GROUP

Response to Pre-Bid Queries
NIT No.: TPCODL / CCG / 23-24 / 100000520

24.01.2024

Tender Description:
RC for supply of LT Distribution Box at TPCODL, TPNODL & TPSODL

The pre-bid queries as received against the referred tender enquiry and CCG/CEQG (TP-Odisha) responses on the same are placed below:

S. No.	Tender Reference	Pre-Bid Query raised by Bidder	CCG/CEQG (TP-Odisha) response
1	Document No:ENG-LV-3024, Clause no -19 for GTP, SI no -19 - Incoming MCCB	<p>In place of 3P MCCB, may kindly be allowed to use 4P MCCB with Microprocessor based Release with in-built E/F Protection. The Technical advantage of having inbuilt CBCT will ensure comprehensive LSIG protection.</p> <p>Alternatively, bidder may be allowed to use 3P MCCB with Microprocessor based Release with Add on / External Earth Fault Module with separate Neutral CT. This will help in cost optimization & avoid the nuisance tripping, which may occur due to challenged / compromised earthing condition at site.</p>	<p>4 Pole MCCBs are not accepted.</p> <p>3P MCCB should have integrated O/L, S/C & E/F Protection with user settable knob.</p>
2	Technical Specifications: SI no -25 - CT	<p>Neutral CT (Protection Class/ 5P10) is missing in BOQ and Technical Specifications. Kindly add a separate line item specifying Neutral CT (5P10 class) for Ground Fault Protection.</p>	<p>Neutral CT is required. But is for metering purpose only. Same is applicable for Phase CTs as well.</p>
3	Tender Document, Page no. 15, Clause no. 10 – Reverse Auctions	<p>Not all the techno-commercially qualified bidders will be allowed to participate in Reverse Auction.</p> <p>Please review and confirm.</p>	<p>No. of bidders allowed to participate in RA process shall be as mentioned in Tender Document, Page no. 15, Clause no. 10 – “Reverse Auctions”.</p> <p>Hence, bidders are advised to quote their most competitive rates while submitting the bids to avoid disqualification from participation in Reverse Auction.</p>

Note:

This document shall be an integral part of the tender and bidder shall submit signed/stamped copy of this document along with technical bid, as a token of acceptance. The tender document stands modified only to the extent stipulated herein above in this document. All other terms & conditions shall be strictly followed as per Bid documents.