

Corrigendum No. – 1

Tender Enquiry No- TPSODL/OT/2024-25/007

Work Description - Rate contract for providing power supply to new cancer care centre building at MKCG Medical, Berhampur.

1) The following clause of the tender is amended.

| Clause no | Existing clause | Amended Clause |
|--|---|--|
| 1.7 Qualification Criteria (<u>Technical Qualification requirements:</u>) | <p>I. Previous Experience: The bidder must have executed, tested and commissioned similar work of same or higher rating for at least 01 Project on Turnkey basis for any utility / companies with a total cumulative value of Rs. 2 cores in last five financial years.</p> <p>Bidder shall submit the Order copies issued by any Power Utility/ Reputed Company.</p> <p><u>Note:</u> Similar jobs must contain UG cabling & RMU installation works of 33 kV or higher voltage level.</p> | <p>I. Previous Experience: The bidder must have received orders for SITC works of same or higher rating for at least 01 Project on Turnkey basis for any utility / companies with a total cumulative value of Rs. 2 cores in last seven financial years.</p> <p>Bidder shall submit the Order copies issued by any Power Utility/ Reputed Company.</p> <p><u>Note:</u> Similar jobs must contain RMU installation / Switchgear installation works of 33 kV or higher voltage level. Bidder must have experience of UG cabling work through HDD method.</p> |
| 2.2 Quantity variation Clause: | <p>There will not be any guarantee on quantity of job. Job has to be carried out on as and when required basis order from TPSODL on the quantity to be specified in the order.</p> | <p>There will not be any guarantee on quantity of job. Job has to be carried out on as and when required basis order from TPSODL on the quantity to be specified in the order.</p> <p>“TPSODL reserves the right to enhance the RC / PO value to the extent of 15% within the contractual period”.</p> |

2) TPSODL replies for pre-bid queries are attached separately.

Warm Regards,

Shubhranshu Shekhar Sahu

Web www.tpsouthernodisha.com

TP SOUTHERN ODISHA DISTRIBUTION LIMITED
(A Tata Power and Odisha Government Joint Venture)

TP SOUTHERN ODISHA DISTRIBUTION LIMITED
(A Joint Venture of Tata Power and Government of Odisha)

Regd./Corp Office: Kamapalli, Courtpet, Berhampur, Ganjam, Odisha – 760 004

Website: www.tpsouthernodisha.com Email: tpsodl@tpsouthernodisha.com

Corporate Identification Number (CIN):U40109OR2020PLC035195, GSTN: 21AAICT3239P1Z1

FORMAT B.1

Format for Technical Pre-Bid Queries

Tender No TPSODL/OT/2024-25/007

Package Name Rate Contract for Providing power supply to new cancer care centre building at MKCG Medical, Berhampur.

| Sr. No. | Detailed Reference to TPSODL Technical Document. Please specify Document No / Clause No / Page No | Description as per Bid Document | Remarks - Query / Clarification | TPSODL Response |
|---------|---|---|---|---|
| 1 | 2 | 3 | 4 | 5 |
| 1 | <p>Page- 6. Technical Qualification requirements:</p> | <p>Previous Experience: The bidder must have executed, tested and commissioned similar work of same or higher rating for at least 01 Project on Turnkey basis for any utility / companies with a total cumulative value of Rs. 2 cores in last five financial years. Note: Similar jobs must contain UG cabling & RMU installation works of 33 kV or higher voltage level</p> | <p>Request to consider Previous Experience as: The bidder must have executed, tested and commissioned similar work of same or higher rating for at least 01 Project on Turnkey basis for any utility / companies with a total cumulative value of Rs. 2 cores in last seven financial years, instead of last five financial years. Similar jobs must contain UG cabling & RMU installation works of 11 kV or higher voltage level, instead of 33 KV or higher voltage level.</p> | <p>The bidder must have received orders for SITC works of same or higher rating for at least 01 Project on Turnkey basis for any utility / companies with a total cumulative value of Rs. 2 cores in last seven financial years. Bidder shall submit the Order copies issued by any Power Utility/ Reputed Company. Note: Similar jobs must contain RMU installation / Switchgear installation works of 33 kV or higher voltage level. Bidder must have experience of UG cabling work through HDD method.</p> |