

<b>Response to Technical Pre-Bid Queries</b>				
<b>Tender No. TPSODL/OT/2023-24/071</b>				
<b>Package Name Supply 33 &amp; 11 KV V cross Arm</b>				
<b>Sr. No.</b>	<b>Detailed Reference to TPSODL Technical Document. Please specify Document No / Clause No / Page No</b>	<b>Description as per Bid Document</b>	<b>Remarks - Query / Clarification</b>	<b>TPSODL Response</b>
<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>
1	ENG-EHV-1034, clause-18- Drawing Page- 8 & 9	4 type 33KV V cross arm drawing given	Confirm which type V Cross arm needed.	Need to maintain the Approx weight mentioned in Technical Specification and only hole position will be decide during detailed Engineering.
2	ENG-HV-2026 clause-18- Drawing Page- 8 & 9	3 type 11 KV V cross arm drawing given	Confirm which type V Cross arm needed.	Need to maintain the Approx weight mentioned in Technical Specification and only hole position will be decide during detailed Engineering.