

## FORMAT B.1

## Format for Technical Pre-Bid Queries

Tender No TPSODL/OT/2024-25/023

Package Name PO/RC for -----

Bidder :

Note : The said format to be used only for Technical Pre-Bid Query. Any Commercial Query has to be strictly in Format B2 Format for Commercial Pre-Bid Query and sent separately

Format to be used for query regarding Technical Pre-Qualification Requirement, Safety Pre-Qualification Requirement, Technical Set of Document

Pre-Bid Query has to be sent in editable Excel file format only

Pre-Bid Query has to be sent through e-mail in TPSODL E-Tender System

Sr. No.	Detailed Reference to TPSODL Technical Document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	TPSODL Response	Bidder's Name & Contact Details
1	2	3	4	5	6
1	<b>DOC. NO.-</b> ENG-HV-33KV & 11kV ,400A M/F Contacts of <b>Vertical AB Switch</b> <b>CLAUSE NO.- 1.0 SCOPE</b> <b>PAGE NO.- 53</b>	<b>3.</b> Male Contact of <b>33 kV, 400 Amps</b> Vertical AB Switches <b>4.</b> Female contacts of <b>33 kV, 400 Amps</b> Vertical AB Switches	REQUIRED QUANTITY NOT MENTIONED IN <b>ANNEXURE - I</b> FOR PRICE BID	<b>Not Required As per Tender documents</b>	
2	<b>DOC. NO.-</b> ENG-HV-33KV & 11kV ,400A M/F Contacts of <b>Vertical AB Switch</b> <b>CLAUSE NO.- 4.0 GENERAL TECHNICAL REQUIRMENTS</b> <b>PAGE NO.- 54</b>	<b>SN NO.-17.</b> Size of flexible tinned copper braid/rope <b>11KV 400Amp. -200 sq.mm</b> <b>33KV 400Amp. -200 sq.mm</b> <b>SN NO.-18.</b> Minimum length of insulated tinned copper braid/rope per phase <b>11KV 400Amp. -As per Requirement</b> <b>33KV 400Amp. -As per Requirement</b> <b>SN NO.-19.</b> Size of fixed contacts <b>11KV 400Amp. -300 sq. mm</b> <b>33KV 400Amp. -300 sq. mm</b> <b>SN NO.-20.</b> Size of Moving contacts <b>11KV 400Amp. -300 sq. mm</b> <b>33KV 400Amp. -300 sq. mm</b>	ALL MESURMENTS ARE IN <b>SQ MM</b> WHICH IS NOT HAVING THE DETAILS LIKE <b>LENGTH, WIDTH,&amp; THICKNESS</b> <b>SN NO. 18 MESURMENTS DETAILS REQUIRED</b>	<b>SN NO.-17.</b> Size of flexible tinned copper braid/rope <b>11KV 400Amp. -200 sq.mm:- 320mm (450g/m)</b> <b>33KV 400Amp. -200 sq.mm:- Not Applicable</b> <b>SN NO.-18.</b> Minimum length of insulated tinned copper braid/rope per phase <b>11KV 400Amp. -As per Requirement:- 320mm (450g/m)</b> <b>33KV 400Amp. -As per Requirement:- Not Applicable</b> <b>SN NO.-19.</b> Size of fixed contacts <b>11KV 400Amp. -300 sq. mm:- 80mmx50mmx8mm (Copper Type Electrolytic with silver plated)(coating thickness not less than 10microns)</b> <b>33KV 400Amp. -300 sq. mm:- Not Applicable</b> <b>SN NO.-20.</b> Size of Moving contacts <b>11KV 400Amp. -300 sq. mm:- 220mmx50mmx8mm (Copper Type Electrolytic with silver plated)(coating thickness not less than 10microns)</b> <b>33KV 400Amp. -300 sq. mm:- Not Applicable</b>	
3	<b>DOC. NO.-</b> ENG-HV-11KV, 200A M/F Contacts of <b>Vertical AB Switch</b> <b>CLAUSE NO.- 4.0 GENERAL TECHNICAL REQUIRMENTS</b> <b>PAGE NO.- 43</b>	<b>SN NO.-17.</b> Size of flexible tinned copper braid/rope <b>11KV 200Amp. -150 sq.mm</b> <b>SN NO.-18.</b> Minimum length of insulated tinned copper braid/rope per phase <b>As per Requirement</b> <b>SN NO.-19.</b> Size of fixed contacts <b>11KV 200Amp. -150 sq. mm</b> <b>SN NO.-20.</b> Size of Moving contacts <b>11KV 200Amp. -150 sq. mm</b>	ALL MESURMENTS ARE IN <b>SQ MM</b> WHICH IS NOT HAVING THE DETAILS LIKE <b>LENGTH, WIDTH,&amp; THICKNESS</b> <b>SN NO. 18 MESURMENTS DETAILS REQUIRED</b>	<b>SN NO.-17.</b> Size of flexible tinned copper braid/rope <b>11KV 200Amp. -150 sq.mm:- 320mm (450g/m)</b> <b>SN NO.-18.</b> Minimum length of insulated tinned copper braid/rope per phase:- <b>320mm As per Requirement</b> <b>SN NO.-19.</b> Size of fixed contacts <b>11KV 200Amp. -150 sq. mm:- 70mmx35mmx6mm (Copper Type Electrolytic with silver plated)(coating thickness not less than 10microns)</b> <b>SN NO.-20.</b> Size of Moving contacts <b>11KV 200Amp. -150 sq. mm:- 220mmx35mmx6mm (Copper Type Electrolytic with silver plated)(coating thickness not less than 10microns)</b>	