

Tender No : TPSODL/OT/2023-24/082				
Package Name: Rate Contract for Supply of various type of HV & LV winding wire/ strip for repairing of various capacity of DTR at DT workshop at TPSODL				
Response of pre bid queries				
Sr. No.	Detailed Reference to TPSODL Technical Document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	TPSODL Response
1	2	3	4	5
1	Annexure I (page 17-18) of NIT documents	In LOT II item list from Serial No: 11 to 22. Various different sizes of AI Strip are mentioned. For eg: 10.65x3.95x6, 11.75x3.95x3, 8.20x2.95x1	Respected Sir, please clarify what does the 3rd value means. please note that in the IS 6162- Part II which is applicable in this case the 3rd value is not given. And the standard size is given as widthheight only no 3rd value is taken. We have enclosed orders and GTP of other board for your ready reference. we humbly request you to please clarify so that we can submit our bid accordingly	Consider only first 2 value for dimension of AI Strip. 3rd value is no of pair.