

CENTRALIZED CONTRACTS GROUP**NIT No.: TPCODL/CCG/23-24/1000000770****Corrigendum- I****NIT No. : TPCODL / CCG / 2023-24 / 1000000770****Rate Contract - Supply of Ring type Current Transformer for Tata Power Odisha Discoms****Dated 11th July 2024****Following changes in Calendar of Events in page no 5 of tender document is made;
1.3 Revised Calendar of Events:**

(b)	Date by which Interested and Eligible Bidder to pay Tender Fee and confirm participation as mentioned in "Procedure to Participate in Tender"	11-07-2024 [15:00 hrs]
(e)	Due date and time of receipt of Bids	16-07-2024 [15:00 hrs]
(f)	Date & Time of opening technical bids	16-07-2024 [16:00 hrs]
(g)	Date & Time of opening of Price of qualified bids	To be notified to the successful bidders

Reply for pre-bid queries;

Sr. No.	Detailed Reference to NIT. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	Tata Power Response
1	2	3	4	5
1	ENG-LV-RESIN CAST RING TYPE CT/CLAUSE NO.4/ Page No.5	GENERAL TECHNICAL REQUIREMENT	POINT NO. 5 for Routine Test & POINT No. 7 for TYPE TEST REPORT: You have mentioned the accuracy Test to be conducted 5%,20%,100% & 120%, however as per IS:2705:1992 as well as latest IS 16227:2016 for C.T.s with C1.0.5S, the accuracy test has also to be conducted @1% of the rated primary current i.e. 1%, 5%, 20%,100% & 120%.	Accuracy test accepted as per IS 2705:1992 & IS 16227:2016

CENTRALIZED CONTRACTS GROUP**NIT No.: TPCODL/CCG/23-24/100000770**

2	Open Tender Notification/ CLAUSE No. 13.1.6/ Page no. 16	DELIVERY PERIOD	You have mentioned Delivery Period of 45 days from the date of receipt of release order/CAT-A issuance, whichever is later. Suppose we are issued a rate contract for the supply of XXX Qty. and simultaneously release order of the same Qty., which means, we have to supply entire Qty. within 45 days. As it may be difficult to supply entire Qty. of Rate Contract within such period, we request you to extend the delivery period up to 90 days or monthly staggered delivery commencing after 30 days of P.O	Delivery Periaod Remains Same as given in Tender
---	--	-----------------	---	--

All other terms and conditions of the above tender shall remain unaltered.

Yours faithfully,

**Head-Contracts
CCG, Bhubaneswar**