

Tender No : TPSODL/OT/24-25/017

Package Name: Rate contract for construction of 2x1.6MVA 33/11 KV PSS at Jodamba under SWAMBHIMAN area of Malkangiri.

Sr. No.	Detailed Reference to TPSODL Tender Document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	TPSODL Response
1	2	3	4	5
1	BOQ: PART C: SUPPLY OF FOLLOWING EQUIPMENT & MATERIALS (As per Technical Specification)	SI,No- 9 1.6 MVA, 33/11kV Power Transformer DYn11 (Outdoor Installation) with Accessories	Against the description quantity not available . Please clarify in this regard. Also please share the Technical specification of 1.6 MVA, 33/11kV Power Transformer as it is not available in the tender document.	PTR shall be provided by TPSODL. The same is mentioned in the tender document.
2		SI.No- 43, 33KV Line DP-2No's 43.1 WPB 160x1160 (11Mtr. Long, 30.44KG/Mtr.) for Station Transformer (GI)	In the description it is mentioned WPB 160 X 1160 . Request to clarify the specification of WPB.	This is a typo error. Please read it as "WPB 160x160 (11Mtr. Long, 30.44KG/Mtr.) for Station Transformer (GI)"
3		Regarding Technical specification for the items.	This is to inform you that, no of technical specification which are provided in the tender document are not opening. Therefore request you kindly provide the technical specification again.	We have uploaded the tender document alongwith the technical specifications in ARIBA. Bidders can download the same.

