

FORMAT B.1

Techno-Commercial Pre-Bid Queries

Tender No TPSODL/OT/ 2023-24/090

Package Name Rate Contract for supply of hardware fitting at TPSODL

Sr. No.	Technical Document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	TPSODL- Odisha DISCOMs' Response
1	2	3	4	5
Technical				
1	Clause no.7.3, Technical specification, Page no.8	Type test- i.)Electrical resistance test, ii.)Heating Cycle test in all hardware fitting items.	Idealy, this type test is not applicable on All hardware fitting.	Specification to be complied. List of Type test should be followed by IS 2486
2	1. Clause no.7,TECHNICAL SPECIFICATION 45 KN T&C HARDWARE FITTING, Page no.5 & 9. & 2. 45KN Rabbit conductor	i.Type test-CPRI/ERDA, ii.Clamp size 149 in drawing, iii.Ball eye in drawing. & 2.Clamp size 149 in drawing,	1. i. Idealy it should be CPRI/ERDA/OTHER GOVT LAB. ii. Clamp upper side length should be 100 instend of 149. iii. There cant be ball eye in T&C type hardware fittng as provide in drawing. 2.Clamp upper side length should be 100 instend of 149.	1. Noted. i.e type test should be conducted from CPRI/ERDA/ NABL. 2. Attached drawing is indicative nature. Supplied material should be a type tested model.i.e BA should submit type test against the supplied model.