Subject:

Pre-bid queries response||Tender No. TPSODL/OT/2024-25/038||supply of accucheck meter

Sr. No.	Cl. No. & Specification	Clarification required	TPSODL Response
	Sr. No. 6	Please confirm 1000 test results is acceptable.	
1.	Test results storage facility - 2000 Test results	Since as per our design, we are providing up to 1000 test results.	Tender specification needs to be complied
2.	Single Phase LT Accucheck Clause 4	As per our design in view of latest technology, for Single Phase ERS, we provide 0.2 accuracy in 200 mA to 80 A in Clamp on CT mode.	
	Sr. No. 8 - Current in Direct Mode using Ring CT (Imin to Imax) - 200m Amp to 10 Amp	In practical scenario, direct mode for testing is not feasible hence we are not providing the same.	Tender specification needs to be complied
	Sr. No. 9 - Current using Clamp on CT (Imin to Imax) - 60m Amp to 500 Amp	Please note that, as asked direct mode 200 mA to 10 A which cover thru Clamp on CT mode. Hence please confirm, only clamp on ct mode is	
		also accepatble.	
3.	Three Phase LT Accucheck	For Three phase LT Accucheck, 300 A Clamp on CT is acceptable.	
	Sr. No. 9 Current using Clamp on CT (Imin to Imax) – 100 / 200 / 300 / 500 A	Please note that, there will be price difference for different rating of CTs i.e. 100 A or 200 A or 300 A or 500 A.	Tender specification needs to be complied – 500A is the requirement
		Hence one specific Max. current rang of 300 A shall be defined.	

	Three Phase combined LT-HT Accuchecks	For Primary clamp on CT 0.5 accuracy is sufficient. Since while testing in primary side of the installation, total accuracy will be <u>Class 1.0</u> (0.5 for LT CT and 0.5 for energy meter) as per the IS12346.	
4.	Clause 4	For Primary Clamp on CT up to 500 A shall be asked.	Tender specification needs to be complied – we have 0.2S meters as well
	Sr. No. 3 Accuracy Class		
	0.05 (Direct CT), 0.2S (Primary Clamp on CT), 0.2S (Secondary Clamp on CT)		
	Cl. No. 7 - operator data entry	Asked no. of digits are depends on design of	Tender
5.	Resolution / No. of characters / digits of parameters	equipment of manufacturer. It shall be acceptable to TPSODL as per the field testing condition, please confirm	specification needs to be complied