

## Pre-bid queries response

Tender No NIT No.: TPSODL/OT/2024-25/057

Package Name Rate Contract for SITC of outdoor Control and Relay Panel at TPSODL.

Sr. No.	Detailed Reference to TPSODL Technical Document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	TPSODL Response
1	2	3	4	5
1	Specification Point no-4.3.7	Relay requirement for SCADA Communication & Other Functionalities	You have already taken Numerical Relay for Transformer differential protection with all protection and communication then what is the use of extra relay .Please confirm.	For Transformer control panel, one relay with minimum 8 CT input compatible to have all protection with communication mentioned against 4.3.6 & 4.3.7 are allowed.
2	Specification Point no-4.12	Tests,Type Test Certificates, You required IP65 enclosure, But as per sample GAD you have taken Canopy	IP65 enclosure canopy not required. So either you take IP55 with Canopy or IP 65 enclosure. Please confirm.	IP 65 Type test as well as enclosure is required, Canopy should be separately welded on top of box enclosure.