

**FORMAT B.1****Format for Technical Pre-Bid Queries****Tender No** TPSODL/OT/2024-25/047**Package Name** **Tender Name - Rate Contract for electrification of additional villages under SETU FY 2023-24 on "Turnkey Contract Basis".****Bidder :** XXXX**Note :** The said format to be used only for Technical Pre-Bid Query. Any Commercial Query has to be strictly in Format B2 Format for Commercial Pre-Bid Query and sent separately

Format to be used for query regarding Technical Pre-Qualification Requirement, Safety Pre-Qualification Requirement, Technical Set of Document

**Pre-Bid Query has to be sent in editable Excel file format only****Pre-Bid Query has to be sent through e-mail in TPSODL E-Tender System**

Sr. No.	Detailed Reference to TPSODL Technical Document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	TPSODL Response
1	2	3	4	5
1	Ref: BOQ SL.No- 80 (Supply of Material) & SI No- 69 (Erection of material)	Suspension Clamp	Against the item Unit of Material Mentioned as 'pair'. Request to clarify whether it is pair / No.	Nos.
2	Ref: BOQ SL.No- 81 (Supply of Material) & SI No- 70 (Erection of material)	Tie Plastic Black size 7.6mmX380mm	Against the item Unit of Material Mentioned as 'Lot'. Request to clarify whether it is Lot / No.	UoM shall be Lot (1 Lot=100 Nos.)
3	Ref: BOQ SL.No- 82 (Supply of Material) & SI No- 71 (Erection of material)	Tie Plastic size 9mmX265mm	Against the item Unit of Material Mentioned as 'Lot'. Request to clarify whether it is Lot / No.	UoM shall be Lot (1 Lot=100 Nos.)
4	Technical Specification	Part-A ENG-HV-96 Specification of Hardware Fitting B&S Type 45KN TPSODL.pdf	Not able to open. Request to provide again.	Re-attached
5	Technical Specification of the Material /Equipment	<b>Technical specifications for the items mentioned below are not available in the tender document</b>	Request to share the Technical specifications.	
		11kV AB Switch 200A 3pole 50Hz Horizontal Type		Attached
		11kV AB Switch 400A 3pole 50Hz Horizontal Type		Attached
		11kV Disc insulator (B&S) 45KN , 70 KN polymer		Attached
		11kV H/W fitting(B&S) 45KN & 70 KN 3 Bolt		Attached
		11kV V cross Arm (GI)		Attached
		11kV V cross Arm (GI) for WPB Pole		Attached
		11kV,5kN pin insulator polymer		Attached
		25 KVA,11/0.43KV(AI) Transformer		Attached
		3 Phase Whole Current MTR Box		Attached
		40mm nominal bore GI pipe (medium gauge) earthing device with 3 mtr .Long		Attached
		Back Clamp for LTDB of length 0.801 mtr		It will be approve at the time of detail engineering based on the Pole Type
		Back Clamp for Transformer belting angle of length 0.576 mtr		It will be approve at the time of detail engineering based on the Pole Type
		CLAMP PG FOR 55 SQMM AAAC		Attached
		CLAMP PG FOR 55 SQMM CONDUCTOR		Attached
		CONDUCTOR 55 SQMM AAA	Attached	
		Eye hook	Attached	

Sr. No.	Detailed Reference to TPSODL Technical Document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	TPSODL Response
		Fish Plate 50X8 mm.,each 0.280 mtr. Length		Attached
		GI Back Clamp for 11kV 'V' Cros Arm		Attached
		GI Back Clamp for 11kV 'V' Cros Arm for WPB Pole		Attached
		Gland for 1.1kV Al 1CX50 Sq.mm		Attached
		Gland for 1.1kV Al 4CX25 Sq.mm		Attached
		Gland for 4Cx50Sqmm CC,DC		Attached
		H.T 11kV Stay set (Complete)		Attached
		H.T Stay clamp		Attached
		H.T Stay Insulator		Attached
		HG Fuse(11KV 200A 3 Pole 50Hz) with PI		Attached
		Lightning Arrester (9kV,10kA) DH Class		Attached
		LT Distribution Box with MCCB for 25KVA S/S		Attached
		Smart Meter 3Ph 4W		Attached
		Flats ,Channels & Angles		Attached