

TPSODL/OT/2025-26/ 2500001026				
Package Name: Rate Contract for supply of 11kV 3C X 185 sq.mm XLPE (A2XFY) Armored cable.				
Response to Techno-Commercial Pre- Bid Queries				
Sr. No.	Detailed Reference to TPSODL Tender Document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	TPSODL Response
1	2	3	4	5
1			The thickness of Copper tape has not been specified in the Technical Specification (TS	Thickness of Copper tape shall be 0.040 mm minimum
2			2.As per IS 7098 Part-2:2011 (Cl. No. 18.3, Table 7), the minimum outer sheath thickness shall be 2.36 mm, instead of 2.52 mm (minimum) as mentioned in TS (Cl. No. 5.8(3)).	Outer Sheath Thickness shall be 2.36 mm minimum
3			3.As per IS 3975:1999 (Cl. No. 9.1(b)), the mass of Zinc coating on formed wire shall be 110 g/m ² , instead of 290 g/m ² mentioned in TS (Cl. No. 5.7(2)). Kindly confirm.	Mass of Zinc Coating on formed wires shall be 110 g/m ² minimum