

## Centralized Contract Group (CCG)

Format No. –  
Revision No. –  
Eff. Date –

**Dated: 26.06.2025**

### Response to Pre-Bid Queries

**Tender no. TPCODL / CCG / 2024-25/1000003174**

**Tender Description: RC for supply of Junction Boxes for CT & PT at TPCODL, TPNODL, TPWODL & TPSODL**

**The pre-bid queries as received against the referred tender enquiry and CCG/CEQG (TP-Odisha) responses on the same are placed below:**

S. No.	Tender Reference page no./clause no.	Tender Reference (Document name/Clause name)	Pre-Bid Query raised by Bidder	CCG/CEQG (TP-Odisha) response
<b>## Technical Queries</b>				
1	Technical specification for CT & PT Junction box /Pg-39/Clause 7.2 & 7.3/Point-ii		In point-ii it is mentioned Insulation resistance test for CT & PT Junction box, <b>kindly clarify for which part of the CT &amp; PT junction box insulation resistance test is required for.</b>	Insulation Resistance (IR) 1)Test: At 500 VDC between all live terminals shorted and body. 2)And Across TB.
2	Technical specification for CT & PT Junction box /Pg-42/Drawing		3 nos of PVC Cable duct and 2 Nos of neutral bus bar are shown in the sample drawing. <b>Please mention the size of PVC Cable duct and Neutral bus bar.</b>	Dimensions are mentioned in the sample drawing. CABLE DUCT (25 x 45 mm).Length of duct shall be as per length of the total TBs. Aluminium Neutral Busbar shall be 25x5 MM and Connected to Earth Stud with 2.5 SQMM. Cu Wire through Lugs.
3	Technical specification for CT & PT Junction box /Pg-37 & Pg-38 /Clause No. 5.1.5 & 5.2.6		The drawing is not matching with the dimensions written in clause no. 5.1.5 and 5.2.6 and there is no clarity. <b>Kindly indicate the dimensions properly in the drawing.</b>	Sample drawing shall prevail. Any modifications may be discussed during detail engineering.
4	Technical specification for CT & PT Junction box /Pg-36 /General Technical requirements/Point-12		In point no. 36 of General technical requirements, details of terminal blocks are mentioned which are mismatching with points 5.1.3 & 5.2.3 of General construction for CT & PT Junction box, due to which there is difficulty in finding a particular product in the Elmex catalogue. <b>Kindly specify the particular terminal block for CT &amp; PT Junction Box and mention it is stud connecting type or dis connecting type as per Elmex catalogue.</b>	Elmex make CATDM4 TB required.

## Centralized Contract Group (CCG)

Format No. –  
Revision No. –  
Eff. Date –

**Dated: 26.06.2025**

### Response to Pre-Bid Queries

**Tender no. TPCODL / CCG / 2024-25/1000003174**

S. No.	Tender Reference page no./clause no.	Tender Reference (Document name/Clause name)	Pre-Bid Query raised by Bidder	CCG/CEQG (TP-Odisha) response
5	Terminal in spare		Do we need to supply terminal in spare also. Pls. inform	No
6	Technical Pre-Qualification Requirements 2.0 Pre- Qualification Criteria clause no 01 :	in-house facilities for routine & acceptance tests as per technical specifications	A. Kindly inform What are the routine & acceptance test reports of Materials are to be complied. B. Do we need to submit undertaking regarding these in-house testing Facilities?	A. Routine and acceptance tests on the junction box are required only. Following tests shall be conducted as routine and acceptance tests.( refer cl.7 of tendered specifications) i) Overall Dimensions Checking ii) Insulation Resistance Tests iii) High Voltage Test at 2500 V, 50 Hz AC for one minute. iv) Galvanisation Tests (If applicable) For Brought out materials Raw material test certificates to be submitted.  B. Yes, undertaking regarding in house testing facilities are to be submitted along with the bId.
7	Clause No. 8, Type Test Certificate		As per tender, All the tests shall be conducted at CPRI/ERDA/Other Govt. Lab as per relevant IS. Kindly confirm Regarding Other Govt.Labs : should we consider Test Reports certified by NABL accredited Lab will be approved in this case or not.	For type tests NABL approved Laboratories are accepted. Routine and acceptance tests shall be witnessed by TP Odisha Discom team.

## Centralized Contract Group (CCG)

Format No. –  
Revision No. –  
Eff. Date –

**Dated: 26.06.2025**

### Response to Pre-Bid Queries

**Tender no. TPCODL / CCG / 2024-25/1000003174**

S. No.	Tender Reference page no./clause no.	Tender Reference (Document name/Clause name)	Pre-Bid Query raised by Bidder	CCG/CEQG (TP-Odisha) response
<b>## Commercial Queries</b>				
9	Delivery of Material		Delivery of CT Junction Box & PT junction box: Whether we have to supply on same location. Or different places in odisha.	The Materials shall be delivered to the respective locations in all 4 DISCOMs as mentioned in Annexure-I
10	Delivery of Material		Do we need to supply all the material in one lot. Pls. confirm	The materials need to be delivered against the RO quantities from each 4 DISCOMs. DISCOM shall issue the RO based on the User's requirement.
11	Delivery of Material		How much time we will get for the delivery completion.	Delivery Period: For 1st RO – Delivery Period shall be 60 days from date of receipt of release order / CAT-A issuance / prototype approval, whichever is later. For subsequent ROs – Delivery Period shall be 45 days from date of receipt of release order.
12	1.3 Calendar of Event		In the NIT it is mentioned that the Pre-bid Query shall be replied on 26-07-2025. But Tender submission date is on 02-07-2025. Pls. clarify the statement.	We acknowledge the Typo Error in this regard. Pre-Bid Queries shall be published on 26-06-2025.
13	EMD Fees		Pls. explain All about EMD fee for the Tender to submitted.	for the details, kindly refer NIT Clause No. 5.1.1 (Page 9 of 226)
14	Guarantee Period		Usually, for these items, Guarantee Period is considered as 24 Months from Date of Supply. But in Clause 13, pt. no. 4 it is mentioned as 60 Months. Kindly clarify.	Guarantee Period shall be, 60 months from the date of last supplies made under the contract.

**Note:**

*This document shall be an integral part of the tender and bidder shall submit signed/stamped copy of this document along with technical bid, as a token of acceptance. The tender document stands modified only to the extent stipulated herein above in this document. All other terms & conditions shall be strictly followed as per Bid documents.*