

Tender No: TPSODL/OT/2025-26/2500001058				
Rate Contract for Supply of Aluminium Lugs of different sizes across PAN TPSODL				
Sr. No.	Detailed Reference to TPSODL Technical Document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	TPSODL Response
1	2	3	4	5
1	Technical Specification for Different Types of Aluminum Lugs F02- (09.07.04)	In GENERAL TECHNICAL REQUIREMENTS not mentioned the Size of J (Total Length)	Please give the Size of J for the all item, We are regulary supply in TPNODL, TPCODL, TPNODL the Lugs with the following size of J Size -25 Total Length - 57 Size -50 Total Length - 72 Size -70 Total Length - 88 Size -95 Total Length - 95 Size -120 Total Length - 108 Size -150 Total Length - 108 Size -185 Total Length - 108 Size -300 Total Length - 130 Size -630 Total Length - 200	Acceptable, provided it is ensured that there shall be no changes in the defined values of E, A, C, D, F, B, H, and G, nor any deviation from the specified material properties
2	TYPE TEST CERTIFICATES	The bidder shall furnish the type test certificates of the individual component for the tests as mentioned as above as per the corresponding standards. All the tests shall be conducted by ERDA /NSIC /National test house lab as per the relevant standards	We are request you to also allow the NABL Lab with NSIC, NTS and ERDA	Only Govt. owned NABL lab is allowed
3	Tolerance	Tolerance for lugs	We are regulary supply in TPNODL, TPCODL, TPNODL the Lugs with the foloowing Tolerance on B, H, G and J : $\pm 5\%$ Tolerance on A, C and E : ± 0.1 mm Tolerance on D & F : 0.3 mm	tolerance is already defined in TS