

Rate Contract for Supply & Installation of Air Conditioner and their accessories across PAN TPSODL locations Tender Enquiry No.: TPSODL/OT/2025-26/2500001043				
Consolidated response for Pre-bid Queries				
Sr. No .	Detailed Reference to TPSODL Technical Document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	TPSODL Response
1	1.7 Qualification Criteria Commercial qualification criteria:	Bidder/OEM should submit the Performance certificate from at least one reputed Organization for Supply & Installation of ACs during last 03 years from the date of bid submission. Bidder shall submit the copy of performance certificate in this regard. Past performance experience at TATA Power and its group company shall supersede feedback from other utilities.	Request you to remove it or allow us to give a Self Declaration against it	Please refer to the Corrigendum -1
2	ANNEXURE-1, SERIAL NO-4	Supply of 5 star 2 Tr Cassette Inverter Air Conditioner with copper tube and power cable as per OEM standard (5 Year Comprehensive warranty at site) Brand: IFB, Voltas, Hitachi, Lloyd, Daikin	OUT OF 5 BRAND MENTIONED IN THE BOQ ONLY ONE BRAND IS PROVIDING 5 STAR INVERTER TYPE CASSETTE AC WHEREAS ALL BRAND IS MANUFACTURING 3STAR INVERTER TYPE CASSETTE WHICH ARE NOT RARE PRODUCT AND THEIR SPARE PARTS WILL EASILY AVAILABLE TO ANYONE.	Vendor to quote as per 5 star rating item.
3	ANNEXURE-1, SERIAL NO-11	Supply & Laying PVC flexible drain pipe	PVC FLEXIBLE PIPE IS USED ONLY FOR SPLIT AC AND PVC HARD PIPE OF ABOUT 31MM DIA WITH APPROPRIATE INSULATION IS BEING USED FOR CASSETTE AC TO AVOID SWEATING IN DRAIN PIPE LINE. IN THE BOQ ONLY FLEXIBLE PIPE MENTIONED.	Please refer to the Corrigendum -2