

## Pre-bid queries response

Tender No NIT No.: TPSODL/OT/2024-25/057

Package Name Rate Contract for SITC of outdoor Control and Relay Panel at TPSODL.

Sr. No.	Detailed Reference to TPSODL Technical Document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	TPSODL Response
1	2	3	4	5
1	Clause No.1 of Technical specification	<b>Scope of work :-</b> The scope of this specification covers all the Technical Requirements of Design, Engineering, Manufacturing, testing at manufacturer's works, packing, forwarding, supply and unloading at site/stores complete with all accessories of outdoor Control & Relay panels at various sites of TPSODL.	We understand that our scope is only supply of CRP's, Installation is not in our scope - Please clarify	This Tender is complete SITC, ITC specification attached.
2	Clause No. 4.11 of Technical specification	<b>TPSODL Preferred Make for CRP Enclosures</b>  <b>S. No.      Make</b> 1            Rittal India 2            Pyrotech Electronics 3            Valrack cabinets 4            Siemens	We will provide our (Ultima) make Enclosure, please accept the same	Noted
3	Clause No. 8.2 of Technical specification	<b>Spares</b>	Please share spare list	Please refer the corrigendum 1 dated 29-03-2025 for details.
4			Clarify below point of scope: 1 - Total no of PSS for 58 CRP	Not in the scope of Plant Engineering
5			2 - Control cable laying scope from CRP to Equipment. 3 - HDPE PIPE Supply scope 4 - Earth digging, Civil work scope 5 - Cable tray laying scope 6 - Earth flat laying scope	Please take ref. from ITC Spec. Filal length will be as per site