

Format for Pre-Bid Queries

Tender Reference No	TPSODL/OT/2024-25/052
Tender Name	Rate Contract for Supply of GI Earthing Pipe 3 MTR 40 MM DIA at PAN TPSODL
Bidder :	

Note : Pre-Bid Query has to be sent in editable Excel file format only
Pre-Bid Query has to be sent through message in Tata Power E-Tender System

Sr. No.	Detailed Reference to Tata Power Technical Document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	Tata Power Response
1	2	3	4	5
1	5. GENERAL CONSTRUCTION: PAGE NO-32	The nut bolt and washer s provided shall be as per the relevant IS.	Required Material mentioned in Tender is Earthing Pipe. But in the mentioned page of the Tender Document, it is specified about Nut, Bolt & Washer. Kindly confirm if the Nut Bolt Washer will be provided along with Earthing Pipe. If Yes, then kindly mention the size of Nut Bolt and Washer to be provided as mentioned in Tender Document.	Nut Bolt not required.
2	Technical Specification For V cross arm 11KV/ 4. GENERAL TECHNICAL REQUIREMENTS / Page No-31	4. Make : JINDAL / TATA	Is there any other approved make can be considered other than the mentioned make. Kindly clarify.	Only JINDAL/TATA make shall be acceptable for GI Pipe instead of V cross arm as mentioned in Column B