

Tender No :- TPSODL/OT/2026-27/2500001226				
Package Name :- Rate Contract for Supply of AB Cable				
Pre-Bid Query Response				
Sr. No.	Detailed Reference to concerned Document . Please specify Document No / Clause No / Page No	Description as per Bid Document	Query / Clarification / Deviation	TPSODL Response
1	2	3	4	5
1	Tender	Rate contract for 1 year	Understand that overall quantity for AB cables are significantly lower compare to other Rate contract, which may not be feasible (even not full truck load) for staggered delivery against various ROs issued from time to time under rate contract. It is suggested that this tender may be considered as general tender instead.	Tender Clause prevails
2	Cl no. 1.3 Calender of Events	Due date & time of receipt of Bids	We request an extension for the submission of the tender by 7-10 days till 12.08.2026 from existing due date of submission of tender i.e. 03.08.2026 as you may be aware of the fact that IEEMA circular for July'26 is expected to be published around 7th Aug'26	Please Refer the Corrigendum
3	Table 3 under technical spec. TPU-D-ENG-LV- 30003	1 C x 35 (P) + 1 C X 25 sq.mm Requirement: LT ABC cable with XLPE insulated Phase core twisted around the insulated/bare neutral cum messenger wire.	Pls clarify, whether it would be bare or insulated.	Insulated neutral cum messenger wire required only.
4	Cl no. 4, Table 3, 17 under technical spec. TPU-D- ENG-LV-30003	Drum length 3C x 35 + 1C x 25 + 1C x 16 mm ² 3C x 50 + 1C x 35 + 1C x 16 mm ²	We propose you to accept 1000 mtr drum length in lieu of 500 mtrs.	TS to be complie
5			Kindly confirm whether this tender is exclusively for the TPSODL division or if Purchase Orders under the rate contract may also be issued by other TP distribution companies such as TPNODL, TPCODL, and TPWODL. We require this clarification to accurately calculate the applicable freight charges.	Only for TPSODL
6			Whether Type Test Reports from an NABL-accredited laboratory are acceptable where CPRI reports are not available	Not Acceptable
7			If Type Test Reports are unavailable for certain sizes, are we still eligible to participate, and what documents or undertaking, if any, must be submitted?:-	Type Test for Higher , Medium & Lower sizes are applicable for this tender and no any undertaking shall be allowed regarding submission of TTR.
8	DOCUMENT NO. 2 Specification_TPU-D-ENV- LG-3003, PAGE NO. 20, UNDER TECHNICAL SPECIFICATION, CLAUSE NO. 8	ALL THE TEST SHALL BE CONDUCTED AT CPRI/ERDA/ANY OTHER REPUTED & EQUIVALENT LAB	VALID TYPE TEST REPORT FROM NSIC OR NTH , A GOVERNMENT APPROVED LABORATORY FOR THE SUBJECT TENDER IS ACCEPTABLE OR NOT.	Accepted however Type tests should have not exceeding 05 years from the date of opening the bid as per CEA guideline Annexure-II
9	1.RATE CONTRACT FOR SUPPLY OF AB CABLE, CALUSE NO. 2.1 PRICE VARIATION CLAUSE, PAGE NO. 8	2.1 PRICE VARIATION CLAUSE, PRICE SHALL REMAIN VARIABLE AS PER IEEMA	PLEASE MENTION THE ACTUAL BASE DATE AS PER IEEMA CIRCULAR	Tender Clause prevails. Please refer tender clause no-2.1