

Replies of Commercial Pre-bid queries

Tender No Tender Enquiry No.: TPSODL/OT/2026-27/ 2500001198

Package Name Rate Contract for performance based 11 kV & LT Network Maintenance & Allied Work, 33 KV Network Maintenance and Operational Assistance of 33/11 kV Sub-Station of TPSODL for 3 years.

| Sr. No. | Detailed Reference to TPSODL Technical Document. Please specify Document No / Clause No / Page No | Description as per Bid Document | Remarks - Query / Clarification | TPSODL Response |
|---------|---|---|--|--|
| 1 | 2 | 3 | 4 | 5 |
| 1 | Due date of Bid submission | 19-06-2026 | Request for time extension till 15-07-2026 for preparation of a comprehensive Techno-commercial Bid | Please refer the revised tender event calendar. |
| 2 | Safety | PPE & Tools | Confirm whether replacement of damaged PPE due to normal wear and tear is reimbursable or included in AMC rates. | Part of AMC Rates |
| 3 | Tender Document | Minimum wage revision | Contract Price should be increased/amended in case of wage revision by Govt. of India | Please refer Tender SCC clause No. 7.1. II |
| 4 | TENDER DOCUMENTS AMC(5. 7.1. Special Conditions of Contract (Page No :17, Point No :2)) | Price shall remain firm for the entire RC Period. However, TPSODL shall pass on only VDA/ minimum wages revision, made by Govt. of Odisha. The cost of other components shall remain firm throughout the Contract Period. | In the event of revision VDA & Minimum wages , the same shall be considered by TPSODL. Please confirm. | Please refer Tender SCC clause No. 7.1. II |
| 5 | TENDER DOCUMENTS Page No :20, Point No: XXVIII | TPSODL reserve the right to deduct an amount equivalent to the gratuity component (excluding GST) of the deployed Service Provider/Business Associate workforce from each invoice | Please mentioned the detailed calculation of the gratuity ,this is required while quoting the rate. | Gratuity is 4.81% of Minimum wages as per prevailing Laws. |
| 6 | TENDER DOCUMENTS Page No :23, Point No: ii | Payment term for line items other than 11KV AMC Works / 33KV AMC Works / PSS Operation fixed charges. | Kindly clarify the payment methodology. Will 100% payment be released against submission of the invoice, or will the payment be disbursed as 90% initially with the remaining 10% released subsequently? | No staggered payment. 100% payment shall be made within 30 days on submission of the following documents duly certified by EIC/DOS/STS. 1.Error free invoice 2.Work completion certificate (if applicable) 3.Vehicle Logbook Sheet & copy of fitness certificate (if applicable) 4.Attendance sheet (if applicable) 5.Supporting documents (if applicable) |
| 7 | Page no. 17 7.1. Special Conditions of Contract (ii) | TPSODL shall pass on only VDA/ minimum wages revision, made by Govt. of Odisha | Revision of wages- It is confirmed that the revision in minimum wages by Govt. Odisha will be considered by TPSODL. Please clarify the same | Please refer Tender SCC clause No. 7.1. II |
| 8 | Page no. 20 7.1. Special Conditions of Contract (XXIX) | During execution of the contract, in case any unforeseen conditions arises for manpower reduction from the fixed AMC services / PSS operation services, the subsequent wages along with additional 5% overhead charges over and above the wages shall be deducted from the invoices | Reduction of wages: Overhead charges should be 2% instead of 5%- Please make it clear | No change |

| Sr. No. | Detailed Reference to TPSODL Technical Document. Please specify Document No / Clause No / Page No | Description as per Bid Document | Remarks - Query / Clarification | TPSODL Response |
|---------|--|---|--|--|
| 9 | Page no. 21 7.1. Special Conditions of Contract (XXXIV) | In case the diesel price variation exceeds $\pm 10\%$, the vehicle hiring charges shall be adjusted only for the variation beyond $\pm 10\%$ as per the following formula: | Fuel price variation - It should be variation beyond 5%. Fuel cost component should be considered as 50% of the vehicle hiring charges instead of 30% as the geographical conditions are very bad and distance are very long | No change |
| 10 | Page no. 24 iii. Payment term for Disconnection squared: © | TPSODL reserves the right to deduct and retain an amount equivalent to the gratuity component (excluding GST) of the deployed BA workforce while processing the 10% payment and, which shall be reimbursed upon submission of a valid claim by the BA employee through the respective BA, subject to prevailing statutory provisions. | Gratuity amount should be borne by the TPSODL, please clarify in this regard. Further is also to submit that the gratuity amount should not be deducted from our Tax Invoice. We have not considered gratuity costing in our earlier tenders till now. | Bidder has to consider the gratuity cost (4.81% of wages) in there Bid. TPSODL reserves the right to deduct and retain an amount equivalent to the gratuity component (excluding GST) of the deployed BA workforce while processing the 10% payment and, which shall be reimbursed upon submission of a valid claim by the BA employee through the respective BA, subject to prevailing statutory provisions. |
| 11 | TPSODL/OT/2026-27/2500001198 B- Financial Pre-Qualification Requirements Page No.7 of 38 tender Document AMC (TPSODL) | The bidder should have Average Annual turnover of at least Rs. 40 Cr. in last 3 Financial Year (FY) i.e. for FY 22-23, FY 23-24 & FY 24-25. Qualification Requirement of Financial Turnover for MSME registered in the State of Odisha shall be reduced to 20% of the existing criteria | Our query concerns the Average Annual Turnover which is 40 Cr. in the last 3 Financial Years for financial qualification requirements in tender TPSODL AMC. We are registered with MSME Odisha. We humbly request that you consider the average annual turnover for the last three financial years to be T3&35 Cr instead of Z40 Cr. This would allow us to meet the criteria | Turnover for MSME registered in the State of Odisha (having UDYAM registration with "OD") shall be reduced to 20% of the existing criteria, i.e. - Average Annual turnover of 8 Cr. in last 3 Financial Year (FY) i.e. for FY 22-23, FY 23-24 & FY 24-25. |
| 12 | Price Bid | Wage revision | Please confirm Amendment of RC and reimbursement of statutory increase in minimum wages, EPF, ESI and labor welfare contributions during contract period. | Any change in statutory taxes, duties and levies during the contract period shall be borne by TPSODL. |
| 13 | HR issue | Gratuity reimbursement | Please confirm regarding reimbursement to AMC manpower . Who will bear the cost of the same | Bidder has to consider the gratuity cost (4.81% of wages) in there Bid. TPSODL reserves the right to deduct and retain an amount equivalent to the gratuity component (excluding GST) of the deployed BA workforce while processing the 10% payment and, which shall be reimbursed upon submission of a valid claim by the BA employee through the respective BA, subject to prevailing statutory provisions. |
| 14 | Payment | Asset addition | Clarify commercial mechanism for additional scope/assets introduced after award. | Additional assets shall be considered as part of the scope of this AMC and need to be maintained by BA whenever added to the respective & applicable network. No separate commercial mechanism is there. |
| 15 | Payment Terms | Bill certification | Request timeline for certification and release of monthly bills. | Please refer the Payment term of Tender |
| 16 | Security Deposit | Retention | Clarify whether retention and performance security are both applicable; if yes, specify limits. | As per tender terms |
| 17 | Penalty | Recovery | Confirm that cumulative penalties shall be capped and shall not exceed monthly AMC value. | Penalty against respective non-compliances are mentioned in respective SOW/SLA. It will not exceed the monthly AMC charges. |
| 18 | Diesel/Fuel | Escalation | Request fuel price variation clause for vehicles deployed round the clock. | Please refer tender SCC clause no 7.2.XXXIV |

| Sr. No. | Detailed Reference to TPSODL Technical Document. Please specify Document No / Clause No / Page No | Description as per Bid Document | Remarks - Query / Clarification | TPSODL Response |
|---------|---|---------------------------------|---|--|
| 19 | GST | Tax treatment | Clarify applicability of GST on statutory reimbursements and penalty deductions. | GST is not applicable on statutory reimbursement & Penalty if any deduction/collection from BA. To comply this, statutory payments challan/receipts should be in the name of TPSODL Only. It should be claimed separately without mix-up with any other transactions. Invoice shall be raised without GST. |
| 20 | Contract Period | Extension | Clarify rate applicability and escalation during contract extension period, if exercised. | The tender is floated for 3 years only. |
| 21 | Insurance | Coverage | Confirm whether insurance cost for manpower and vehicles is deemed included in BOQ. | BA may consider the cost of insurance in their bid. No separate line item required. |
| 22 | Mobilization | Startup period | Request reasonable mobilization period before SLA measurement starts. | BA should be ready to mobilize all the required resources within 15 days of issuance of LOI/RC. |
| 23 | Tender documents | | Statutory wage revision reimbursement is not explicitly covered. | Please refer tender SCC clause no 7.2.II |
| 24 | Tender documents | | Fuel escalation mechanism is absent. | Please refer tender SCC clause no 7.2.XXXIV |
| 25 | Tender documents | | Payment terms and bill certification timelines require clarification. | Please refer the Payment term of Tender |
| 26 | Tender documents | | Penalty cap should be defined. | As per revised SLA along with issued corrigendum. |
| 27 | Tender documents | | Additional scope pricing mechanism should be specified. | Please refer the Payment term of Tender |
| 28 | Tender documents | | Contract extension rate applicability should be clarified. | The tender is floated for 3 years only. |
| 29 | Tender documents | | Insurance cost responsibility should be explicitly confirmed. | BA will borne the insurance cost. BA may consider the cost of insurance in their bid. |
| 30 | Tender documents | | Mobilization period before SLA measurement starts should be clarified. | BA should be ready to mobilize all the required resources within 15 days of issuance of LOI/RC. |
| 31 | Price Bid | EPF/ESI | Confirm reimbursement of increase in statutory contributions. | Any change in statutory taxes, duties and levies during the contract period shall be borne by TPSODL. |
| 32 | Payment | Bill Processing | Specify timeline for bill certification and payment release. | Please refer the Payment term of Tender |
| 33 | Payment | Running Bills | Clarify documents required for monthly bill processing. | Please refer the Payment term of Tender |
| 34 | Commercial | Asset Addition | Clarify rates applicable for future asset additions. | Additional assets shall be considered as part of the scope of this AMC and need to be maintained by BA whenever added to the respective & applicable network. No separate additional cost shall be extended. |
| 35 | Commercial | Asset Reduction | Clarify treatment of scope reduction during contract period. | As per tender T & Cs |
| 36 | Commercial | Fuel Escalation | Request diesel/fuel price variation clause. | Please refer tender SCC clause no 7.2.XXXIV |
| 37 | Commercial | Vehicle Cost | Clarify reimbursement for statutory changes in vehicle taxes. | As per tender T & Cs |
| 38 | Commercial | Insurance | Specify insurance coverage required and whether included in rates. | As per tender document. BA will bear the insurance cost. BA may consider the cost of insurance in their bid. |
| 39 | Commercial | Performance Security | Clarify security deposit value and validity period. | Please refer tender SCC clause no 7.2.XV |
| 40 | Commercial | Retention Money | Clarify applicability and maximum retention amount. | As per tender document. |
| 41 | Commercial | Penalty | Confirm overall cap on cumulative SLA deductions. | Maximum invoice value is the maximum Cap. |

| Sr. No. | Detailed Reference to TPSODL Technical Document. Please specify Document No / Clause No / Page No | Description as per Bid Document | Remarks - Query / Clarification | TPSODL Response |
|---------|---|---------------------------------|---|---|
| 42 | Commercial | GST | Clarify GST treatment on statutory reimbursements. | No, GST is not applicable on reimbursement of statutory payments which is made to third party on behalf of TPSODL. But the challans/receipts should be generated in the name of TPSODL only. It should be claimed separately without mix-up with any other transactions. Invoice shall be raised without GST. |
| 43 | Commercial | GST | Clarify GST applicability on penalty deductions. | GST is not applicable on penalty and also on LD deductions. |
| 44 | Commercial | Mobilization | Request minimum 30-day mobilization period before SLA start. | No change |
| 45 | Commercial | Extension | Clarify rate escalation during contract extension. | The tender is floated for 3 years only. |
| 46 | Commercial | Termination | Clarify compensation mechanism for early termination. | Tender terms & conditions shall prevail |
| 47 | Commercial | Additional Manpower | Clarify payment basis for utility-directed deployment. | Paid separately through variable / on-call line item. |
| 48 | Commercial | Night Emergency | Clarify whether emergency restoration is included in AMC rates. | This Tender is a performance-based AMC for 33 kV, 11kV, LT & PSS operations. BA shall provide the minimum indicated manpower as mentioned in the requirement. However, to comply with SLA timelines & performance, BA shall increase its manpower & resources at no additional cost. If any additional items are to be deployed by the BA, separate orders will be placed for variable items to mitigate emergency events, subject to prior approval from TPSODL management. |
| 49 | Commercial | Consumables | Identify consumables to be supplied by utility. | Consumables to be in BA's scope are specified in tender document. |
| 50 | Commercial | Payment Security | Clarify interest provision for delayed payments. | Not applicable for this contract |
| 51 | Commercial | Price Variation | Request CPI/WPI-based escalation for long-duration contract. | Not applicable for this contract |
| 52 | Commercial | BOQ | Clarify whether quoted rates are all-inclusive. | Base rates & taxes are to be specified separately as per BOQ. Accordingly unpriced Bids to be furnished along with technical bid. |
| 53 | Commercial | Taxes | Clarify treatment of future statutory taxes and levies. | Please refer GCC |
| 54 | Commercial | Change in Law | Request change-in-law protection clause. | Not applicable for this contract |

Replies for Technical Pre-Bid Queries
Tender No **Tender Enquiry No.: TPSODL/OT/2026-27/ 2500001198**
Package Name **Rate Contract for performance based 11 kV & LT Network Maintenance & Allied Work, 33 KV Network Maintenance and Operational Assistance of 33/11 kV Sub-Station of TPSODL for 3 years.**

| Sr. No. | Detailed Reference to TPSODL Technical Document. Please specify Document No / Clause No / Page No | Description as per Bid Document | Remarks - Query / Clarification | TPSODL Response |
|----------|---|---------------------------------|--|--|
| 1 | 2 | 3 | 4 | 5 |
| 1 | SOW & SLA | Manpower deployment | Annexure manpower appears fixed irrespective of asset growth during contract. Clarify whether additional manpower due to new feeders/DTRs will be paid separately. | This Tender is performance based AMC for 33 kV, 11kV,LT & PSS operations. BA shall provide minimum indicated manpower as mentioned in the requirement. However in order to comply to SLA timelines & SLA performance BA shall increase its manpower & resources without any additional cost implication. |
| 2 | SLA | Penalty | Clarify whether SLA penalties are capped at a maximum percentage of monthly bill and provide overall penalty ceiling. | Maximum invoice value is the maximum Cap. |

| Sr. No. | Detailed Reference to TPSODL Technical Document. Please specify Document No / Clause No / Page No | Description as per Bid Document | Remarks - Query / Clarification | TPSODL Response |
|---------|---|--|---|---|
| 3 | SOW | Breakdown restoration | Define exclusions for force majeure events such as cyclone, flood, law & order issues, road blockage and third-party damages. | This Tender is a performance-based AMC for 33 kV, 11kV, LT & PSS operations. BA shall provide the minimum indicated manpower as mentioned in the requirement. However, to comply with SLA timelines & performance, BA shall increase its manpower & resources at no additional cost. In case of any force majeure event, If any additional items are to be deployed by the BA, separate orders will be placed for variable items to mitigate force majeure events, subject to prior approval from TPSODL management. |
| 4 | SOW | Asset addition | Clarify payment mechanism for new feeders, DTRs, LT lines and PSS assets added during contract period. | This Tender is performance based AMC for 33 kV, 11kV,LT & PSS operations. BA shall provide minimum indicated manpower as mentioned in the requirement. However in order to comply to SLA timelines & SLA performance BA shall increase its manpower & resources without any additional cost implication. |
| 5 | Digital Applications | Mobile phones/apps | Clarify whether TPSODL will provide software licenses, SIM-based applications and data integration support. | Details are already mentioned in the tender document. |
| 6 | 33kV PSS Operation | Operator responsibility | Clarify liability of BA in case of equipment failure not attributable to operator negligence. | EIC will be the final authority to decide the same. |
| 7 | SOW | Vegetation management | Clarify extent and frequency of vegetation clearance and whether disposal charges are payable separately. | Details are already mentioned in the tender document. If any additional items are to be deployed by the BA, then separate orders will be placed on variable items, subject to prior approval from TPSODL management. |
| 8 | SLA | Measurement methodology | Request detailed KPI calculation sheet with examples for availability, restoration and safety performance. | Details are already mentioned in the SLA Part of the tender document. |
| 9 | Resources | Vehicle deployment | Clarify fuel escalation/payment mechanism during contract tenure. | Details are already mentioned in the tender document. |
| 10 | Safety Compliance | Buffer stock | Clarify inspection methodology and penalty applicability for temporary shortages due to field replacement. | Details are already mentioned in the tender document. |
| 11 | Training | Competency requirements | Request minimum qualification matrix and acceptance criteria for replacement manpower. | Details are already mentioned in the tender document. |
| 12 | Scope of work | Payment of Additional work in case of exigency | Force majeure treatment during cyclone restoration (particularly important for Odisha DISCOM contracts) | This Tender is a performance-based AMC for 33 kV, 11kV, LT & PSS operations. BA shall provide the minimum indicated manpower as mentioned in the requirement. However, to comply with SLA timelines & performance, BA shall increase its manpower & resources at no additional cost. In case of any force majeure event, If any additional items are to be deployed by the BA, separate orders will be placed for variable items to mitigate force majeure events, subject to prior approval from TPSODL management. |
| 13 | 11kV AMC SOW | Network Expansion | Whether manpower and vehicles shall be increased proportionately for newly added assets? | This Tender is a performance-based AMC for 33 kV, 11kV, LT & PSS operations. BA shall provide the minimum indicated manpower as mentioned in the requirement. However, to comply with SLA timelines & performance, BA shall increase its manpower & resources at no additional cost. |
| 14 | 11kV AMC SLA | SLA Applicability | Whether SLA shall apply during force majeure conditions such as cyclone, flood and law & order disturbances? | Exemptions will be provided, subject to approval from TPSODL management. |

| Sr. No. | Detailed Reference to TPSODL Technical Document. Please specify Document No / Clause No / Page No | Description as per Bid Document | Remarks - Query / Clarification | TPSODL Response |
|---------|---|---------------------------------|--|---|
| 15 | 11kV AMC SLA | Penalty Cap | Specify maximum cumulative SLA deduction permissible per month. | Details are already mentioned in the tender document. |
| 16 | 11kV AMC | Breakdown Restoration | Clarify exclusions where materials are not available from TPSODL stores. | It will not be attributable to the BA. However respective incidents should be certified by EIC. |
| 17 | 11kV AMC | Shutdown Approval | Whether outage approval delays by utility shall be excluded from restoration time. | It will not be attributable to the BA. However respective incidents should be certified by EIC. |
| 18 | 11kV AMC | Consumer Complaints | Define responsibility matrix for consumer-side defects. | It will not be attributable to the BA. However respective incidents should be certified by EIC. |
| 19 | 11kV AMC | Vegetation Management | Specify frequency and disposal responsibility of tree trimming. | Details are already mentioned in the tender document. Frequency will be decided by the EIC/DOS. |
| 20 | 11kV AMC | Patrolling | Clarify minimum patrolling frequency and reporting format. | Details are already mentioned in the tender document. Frequency will be decided by the EIC/DOS. |
| 21 | 11kV AMC | Tools & Tackles | Clarify replacement responsibility for damaged tools due to normal wear and tear. | It is under the BA Scope. Details are already mentioned in the tender document. |
| 22 | 11kV AMC | Safety Stock | Clarify inspection and penalty methodology for PPE buffer stock. | All the PPEs, Testing Instruments, T&Ps will be deployed only after the approval provided by the EIC/Safety/DOS. Details are already mentioned in the tender document. |
| 23 | 11kV AMC | Mobile App | Whether TPSODL will provide application licenses and user IDs. | Details are already mentioned in the tender document. |
| 24 | 11kV AMC | Data Connectivity | Whether mobile data/SIM expenses are included in quoted rates. | The same has incorporated under AMC fixed Charges. There is no separate line item for this. |
| 25 | 11kV AMC | Night Breakdown | Clarify requirement of dedicated emergency gangs for each division. | This Tender is a performance-based AMC for 33 kV, 11kV, LT & PSS operations. BA shall provide the minimum indicated manpower as mentioned in the requirement. However, to comply with SLA timelines & performance, BA shall increase its manpower & resources at no additional cost. If any additional items are to be deployed by the BA, separate orders will be placed for variable items to mitigate emergency events, subject to prior approval from TPSODL management. |
| 26 | 11kV AMC | Training | Minimum qualification criteria for replacement manpower. | Mandatory Comprehensive training to be ensured for all employees. If the training has already been completed, a refresher session is to be ensured before the deployment |
| 27 | 33kV AMC | PSS Operation | Clarify liability for equipment failure due to ageing or manufacturing defects. | It will not be attributable to the BA. However, the BA has to ensure the effective maintenance of the equipment on time. However, respective incidents should be certified by EIC. |
| 28 | 33kV AMC | Operator Deployment | Whether reliever operators are mandatory and included in manpower count. | This Tender is a performance-based AMC for 33 kV, 11kV, LT & PSS operations. BA shall provide the minimum indicated manpower as mentioned in the requirement. However, to comply with SLA timelines & performance, BA shall increase its manpower & resources at no additional cost. |
| 29 | 33kV AMC | Relay Operations | Clarify authorization limits for BA operators. | Details are already mentioned in the tender document. |
| 30 | 33kV AMC | Emergency Restoration | Define scope where OEM intervention is required. | It will not be attributable to the BA. The OEM co-ordination and requirement will be decided by the EIC/DOS. |

| Sr. No. | Detailed Reference to TPSODL Technical Document. Please specify Document No / Clause No / Page No | Description as per Bid Document | Remarks - Query / Clarification | TPSODL Response |
|---------|---|---|---|---|
| 31 | 33kV AMC | Safety Responsibility | Clarify accountability for permit-to-work issuance. | Details are already mentioned in the tender document. |
| 32 | Common | Manpower Verification | Frequency and methodology of attendance verification. | Details are already mentioned in the tender document. |
| 33 | Common | Resource Audit | Clarify notice period before resource inspections. | Details are already mentioned in the tender document. However, the frequency of the resources inspection will be decided by the EIC. |
| 34 | Common | HSE Compliance | Clarify treatment of historical safety incidents prior to contract award. | The BA should take care of any carry-forward disability or treatment cases arising out of the previous contract period. |
| 35 | Common | Performance Measurement | Provide KPI calculation examples for all SLA parameters. | Details are already mentioned in the tender document. |
| 36 | Common | Scope Boundary | Provide activity-wise responsibility matrix between utility and BA. | Details are already mentioned in the tender document. |
| 37 | Scope of Works and Service Level Agreement (11kV AMC) Page No :1 (Point No :1.3 a) | The Streetlight Switching On/OFF at the site will be in the scope of BA, the BA has to ensure that the same is switched on & OFF timely as per the timelines shared by the EIC. | Kindly clarify the estimated number of street-light switching points and whether additional manpower shall be considered for these activities or not. | No additional cost implication to be considered for this activity. It is a part of the AMC Fixed Cost. |
| 38 | Scope of Works and Service Level Agreement (11kV AMC) Page No :11 (Note) | BA Shall deploy specialized manpower for cutting big trees including coconut trees/palm/ bamboo | Kindly clarify whether for such activities it will be included in price bid or separate line item. | No additional cost implication to be considered for this activity. It is a part of the AMC Fixed Cost. If any additional items are to be deployed by the BA, separate orders will be placed for variable items, subject to prior approval from the TPSODL management. |
| 39 | Scope of Works and Service Level Agreement3. Page No :13 (Point No :35) | Jointer for all Cable Jointing activities is in the Scope of the BA. | Please clarify expected annual quantities of HT and LT cable jointing activities included under AMC. | We have already provided the asset details, and the quantity will be as per the fault occurrence at the field. It is a part of the AMC Fixed Cost. |
| 40 | Scope of Works and Service Level Agreement (33kV AMC)(Page :18) | In case of 33kV Cable failure, BA Manpower will be responsible for excavation required for exposing cable fault. | Quantity or details to freeze the budget as we have to quote the firm price. | We have already provided the asset details, and the quantity will be as per the fault occurrence at the field. It is a part of the AMC Fixed Cost. If any additional items are to be deployed by the BA, separate orders will be placed for variable items, subject to prior approval from the TPSODL management. |
| 41 | Page no. 10 2.0 Evaluation Criteria (g) | Bidder should maintain a justified margin on their costing which will take care of various factors i.e. Statutory Licenses, GPA Policy, conveyance, Overhead, Interest on Working Capital, Profit etc. In case it is observed that if any bidder has quoted prices which is unviable as assessed by TPSODL's evaluation committee, following shall be further course of action. | It will be better if TPSODL provide its minimum estimated cost of the tender . | Vendor has to envisage the total scope & SLA . Accordingly based on past experience BA has to participate. |
| 42 | SOW and SLA 11KV AMC | T&P for Vehicles | 1)Most of the items are mentioned as per vehicle and there are six types of vehicles please confirm for which vehicles tools are to be provided and which vehicles is considered to be for AMC. | Details of vehicles are already mentioned in the Annexure-C for the tender document. The numbers & types of tools required are mentioned in the "Revised list of Tools & Tackles" in Corrigendum-1. |
| 43 | SOW and SLA 11KV AMC | T&P for Vehicles | 2) As for DC team one EV has been recommended Kindly confirm that TPSODL provide the provision of its charging. Pl. may also be confirmed that proper service & maintenance infrastructure of the companies are available at all the locations these vehicles are to be deployed. | Tata Magic or equivalent Vehicle may be considered. Please refer to the BOQ Amendment-2 & Annexure-C (Amended Resource List of AMC) |

| Sr. No. | Detailed Reference to TPSODL Technical Document. Please specify Document No / Clause No / Page No | Description as per Bid Document | Remarks - Query / Clarification | TPSODL Response |
|---------|---|---|--|--|
| 44 | Technical specification | Arc Flash Suit _Technical Specification Details final | Arc Flash Suit:- Kindly confirm where it is to be used as it is not mentioned in T&P/PPE List of 11kv & 33 kv List. | Arc Flash Suit (PPE) is not under the Scope of the BA. It will be provided by the TPSODL, but its usage by the AMC manpower will be ensured by the BA. |
| 45 | 5. BoQ Price Bid - Annexure-1 | Annexure 1 price Bid format | Price bid:- Quantity of some 4 wheelers are 1 (Coloured in Yellow), Kindly confirm the quantity. As per scope of work quantity should be 0 instead of 1. | The Colour has no relevance, and the quantity is already provided in the BOQ. Kindly Consider the Quantity. |
| 46 | Annexure F for T&P | Double Insulated Tools | Please explain : what is double insulation means and which companies double insulated tools available in the market and also what is the cost difference between both the tools. | "Revised list of Tools & Tackles" is attached to the Pre-bid query. Kindly consider the same. |
| 47 | | | Some of Queries related to T& P are enclosed in the respective T& P Sheet. | The revised T&Ps list is attached to the Corrigendum-1. Kindly consider the same. |
| 48 | **** | | ***** There is a huge difference between T&P specifications of TPSODL & TPCODL tender no. : TPCODL/P&S/2026-27/1000009868. So you are requested to look into the matter and make changes so that tender's T&P costing may not be on higher side | The revised T&Ps list is attached in the Corrigendum-1 |
| 49 | BOQ | EV Vehicle | EV Vehicle Charging & Coverage is an issue Which Limits its uses in Vast Area. As TPSODL Area is vast, There will be certain Problem will arise , Its requested make it Optional | Tata Magic or equivalent Vehicle may be considered. Please refer to the BOQ Amendment-2 & Annexure-C (Amended Resource List of AMC) |